

OFFICE OF THE STATE ENGINEER
COLORADO DIVISION OF WATER RESOURCES

818 Centennial Bldg., 1313 Sherman St., Denver, Colorado 80203
(303) 866-3581

LIC

WELL PERMIT NUMBER 11057 . R-R
DIV. 1 WD 1 DES. BASIN MD

APPLICANT

ROY ROTHE
24334 WCR 61
KERSEY, CO 80644-

(970) 352-6061

APPROVED WELL LOCATION

WELD COUNTY

NE 1/4 SE 1/4 Section 30
Township 5 N Range 63 W Sixth P.M.

DISTANCES FROM SECTION LINES

1350 Ft. from South Section Line

1320 Ft. from East Section Line

UTM COORDINATES

Northing:

Easting:

PERMIT TO CONSTRUCT A WELL

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT

CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not assure the applicant that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-90-137(2) for the replacement of an existing well, permit no. 11057-R (decreed by the Division 1 Water Court as Rothe Well no. 3-11057, case no. W-2609). Upon completion of the new well, the old well must be plugged and abandoned in accordance with Rule 16 of the Water Well Construction Rules. A Well Abandonment Report form must be submitted within sixty (60) days of abandonment of the old well.
- 4) Approval of this replacement well permit shall not result in an expanded use of ground water. The use of ground water from this well is restricted to the irrigation of 80 acres in the SE 1/4, Sec. 30, Twp. 5 N, Rng. 63 W, Sixth P.M.
- 5) The maximum pumping rate of this well shall not exceed 890 GPM (1.98 CFS).
- 6) The annual amount of ground water to be appropriated shall not exceed 240 acre-feet.
- 7) Production is limited to the alluvium. The depth of this well shall not exceed 120 feet or the depth at which sandstone or shale is first encountered, whichever comes first.
- 8) The owner shall mark the well in a conspicuous place with well permit number(s), name of the aquifer, and court case number(s) as appropriate. The owner shall take necessary means and precautions to preserve these markings.
- 9) This well shall not be pumped unless included in a court approved plan for augmentation or a substitute water supply plan approved by the State Engineer.
- 10) A totalizing flow meter must be installed on this well and maintained in good working order. Permanent records of all diversions must be maintained by the well owner (recorded at least annually) and submitted to the Division Engineer upon request.
- 11) This replacement well shall not be constructed any closer to any other existing well than the well it is replacing, if such other well is within 600 feet of the replacement, is completed in the same aquifer, and is not owned by the applicant.
- 12) This well shall be constructed not more than 200 feet from the location decreed for Rothe well no. 3-11057 in case no. W-2609.
- 13) This well is subject to administration by the Division Engineer in accordance with applicable decrees, statutes, rules, and regulations.

JMW 5/16/02

APPROVED
JMW

He D. Lopez
State Engineer

Kevin A. Rein
By

Receipt No. 0492166

DATE ISSUED, **MAY 16 2002**

EXPIRATION DATE **MAY 16 2003**