

Form No. GW/S-25

OFFICE OF THE STATE ENGINEER
COLORADO DIVISION OF WATER RESOURCES
818 Centennial Bldg., 1313 Sherman St., Denver, Colorado 80203
(303) 866-3581

1380

WELL PERMIT NUMBER 241579 - A
DIV. 1 WD 1 DES. BASIN MD

APPLICANT

BOB E. WHITE
3315 33AVE CT.
GREELEY, CO 80634-

APPROVED WELL LOCATION

WELD COUNTY
NW 1/4 SE 1/4 Section 35
Township 8 N Range 62 W Sixth P.M.

DISTANCES FROM SECTION LINES

2560 Ft. from South Section Line
2550 Ft. from East Section Line

UTM COORDINATES

Northing: Easting:

PERMIT TO CONSTRUCT A WELL

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT

CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not assure the applicant that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-92-602(3)(c) for the relocation of an existing well, permit no. 241579. The old well must be plugged in accordance with Rule 16 of the Water Well Construction Rules within ninety (90) days of completion of the new well. The enclosed Well Abandonment Report form must be completed and submitted to affirm that the old well was plugged.
- 4) The use of ground water from this well is limited to the watering of livestock on a farm or ranch.
- 5) The maximum pumping rate of this well shall not exceed 15 GPM.
- 6) This well shall be constructed not more than 200 feet from the location specified on this permit.

6.11.2002
I.C.

APPROVED
IDC

Hal D. Simpson

State Engineer

Joana Comanovic

Receipt No. 0493545B

DATE ISSUED

JUN 11 2002

By

EXPIRATION DATE

JUN 11 2004