

WELL CONSTRUCTION AND TEST REPORT
STATE OF COLORADO, OFFICE OF THE STATE ENGINEER

For Office Use only

9200811
RECEIVED

MAR 04 2002

WATER RESOURCES
STATE ENGINEER
COLO.

1. WELL PERMIT NUMBER 234461

2. OWNER NAME(S) Robert & Dixie Cherry
Mailing Address PO Box 5358
City, St. Zip Durango CO 81303
Phone (970) 759-3320

3. WELL LOCATION AS DRILLED: NE 1/4 SW 1/4, Sec. 10 Twp. 33 N, Range 8W NMPM
DISTANCES FROM SEC. LINES:
160.5 ft. from 3 (north or south) Sec. line. and 2810 ft. from E (east or west) Sec. line. OR
SUBDIVISION: _____ LOT _____ BLOCK _____ FILING(UNIT) _____
STREET ADDRESS AT WELL LOCATION: _____

4. GROUND SURFACE ELEVATION _____ ft. DRILLING METHOD Rotary
DATE COMPLETED 8-20-01 TOTAL DEPTH 220 ft. DEPTH COMPLETED 220 ft.

5. GEOLOGIC LOG:

Depth	Description of Material (Type, Size, Color, Water Location)
<u>1-12</u>	<u>Top Soil</u>
<u>12-220</u>	<u>Shale</u>
	<u>H2O</u>
	<u>60'</u>

6. HOLE DIAM. (in.) From (ft) To (ft)

<u>1 7/8</u>	<u>40</u>	<u>220</u>
<u>9"</u>	<u>1</u>	<u>40'</u>

7. PLAIN CASING

OD (in)	Kind	Wall Size	From(ft)	To(ft)
<u>5</u>	<u>steel</u>	<u>1.088</u>	<u>1</u>	<u>20</u>
<u>4 1/2</u>	<u>PVC</u>	<u>1.200</u>	<u>20</u>	<u>60</u>

PERF. CASING: Screen Slot Size:

<u>4 1/2</u>	<u>PVC</u>	<u>1.200</u>	<u>60</u>	<u>220</u>
--------------	------------	--------------	-----------	------------

8. FILTER PACK:

Material Round Rock
Size 28
Interval 60-220

9. PACKER PLACEMENT:

Type _____
Depth _____

10. GROUTING RECORD:

Material	Amount	Density	Interval	Placement
<u>Cement 8528</u>	<u>8-1</u>	<u>1-40</u>	<u>Dump</u>	

REMARKS: _____

11. DISINFECTION: Type HTH Amt. Used 2 CDS

12. WELL TEST DATA: ☐ Check box if Test Data is submitted on Form No. GWS 39 Supplemental Well Test.
TESTING METHOD AIR LIFT
Static Level 60 ft. Date/Time measured 8/10/2001 Production Rate 2 gpm.
Pumping level: _____ ft. Date/Time measured _____ Test length (hrs.) 1
Remarks _____

13. I have read the statements made herein and know the contents thereof, and that they are true to my knowledge. [Pursuant to Section 24-4-104 (13)(a) C.R.S., the making of false statements herein constitutes perjury in the second degree and is punishable as a class 1 misdemeanor.]

CONTRACTOR DAK DRILLING Phone (970) 247-9685 Lic. No. 858
Mailing Address 2000 CR 308 Dgo CO 81303

Name/Title (Please type or print)	Signature	Date
<u>DOUG RATHJEN/owner</u>	<u>Doug Rathjen</u>	<u>2-20-02</u>