

April 1, 2014

Chris Clark – Operations Manager  
OXY USA WTP LP  
760 Horizon Drive, Suite 101  
Grand Junction, CO 81506

Subject: Emergency Access – Oxy's Pond 13 E/W Facility

Dear Mr. Clark,

This letter is to address Oxy's Pond 13 E/W facility and its potential access restrictions. The DeBeque Fire Protection District has been familiarized with the location, terrain, and any access issues that may be associated with Pond 13 E/W and is confident that the property provides adequate space for any of the departments brush units, or other four-wheel or all-wheel drive equipment vehicles. The fire departments vehicles are similar to Oxy's fleet Vehicles and will provide sufficient means for access to the site. In any event where the DFPD vehicles could not directly access the Facility, the District has sufficient hoses to access a fire within the Facility. The DFPD does not see any issue with the amount of space available at this location, and therefore does not see any issue with the variance request that this letter pertains to. Please feel free to contact me if you have any questions, comments, or concerns regarding this letter.

Sincerely,



Nick Marx

Fire Chief  
DeBeque Fire Protection District