




Facility ID: 426403

REPORT OF UNDESIRABLE EVENT

NTL-3A (EFFECTIVE MARCH 1, 1979)



To: District Manager, B.L.M., Fluid Minerals, P.O. Box 248, Craig, Colorado 81626  
From: Chevron U.S.A. Inc., P. O. Box 599, Denver, Colorado 80201

1. Spill X Discharge \_\_\_\_\_ Blowout \_\_\_\_\_ Accident \_\_\_\_\_ Fire or Explosion \_\_\_\_\_

2. BBLS Discharged: 300 bbls prod. water BBLS Lost: 300 bbls

3. Contained on location: Yes \_\_\_\_\_ No X

4. Date and time of event: 3/11/87 11:00 P.M.

5. Date and time reported to B.L.M.: 3/12/87 10:30 A.M.

6. Location of event: Main Water Plant, SE NE, Sec 32, R102W, T1N

7. Specific nature and cause of event

Lost power to main water plant, 12" line to the solar turbines burst, water ran out of building into drainage ditch, overflowed ditch and ran into Stinking Water Creek.

8. Describe resultant damage:

N/A

9. Time required for control of event: ± 30 minutes

10. Action taken to control and contain:

Restored power, repaired line and will repair ditch to make sure water goes to pits

11. Action taken to prevent recurrence:

N/A

12. Cause of death:

N/A

\*13. Other agencies notified:

Colorado Department of Health, Water Quality Control, Denver, Colorado  
Colorado Oil & Gas Conservation Comm. Denver, Colorado (Written report only)

14. Other pertinent information:

Signature T.L. Hurst Date 4/2/87

T.L. Hurst

Title Area Supervisor

\* A COPY OF THIS FORM WAS MAILED TO EACH AGENCY LISTED IN PARAGRAPH 13 ABOVE.