

Crossen, Tammie Lee

From: Lanoue, Rick M. (LRIM)

Sent: Thursday, December 17, 2015 2:57 PM

To: Crossen, Tammie Lee

Subject: Rooth Lateral Post-Repair Static Test

Danny Jackson, Waggoner, District A, performed a 15 minute Static Test on the Rooth Lateral while returning it to service this afternoon.

Line pressure was normal and stable at 1680#.

We consulted with FE, then replaced the 8" Cement-lined section that leaked with some 6" Cement Lined.

Rick M. LaNoue

Rangely Maintenance Planner

970-675-3723, Fax 675-3800, Cell 970-629-2992