

From: [Brent Sydow](#)
To: [Derek Petrie](#)
Cc: [Paul Gottlob](#)
Subject: RE: Powerline Saftey Setback
Date: Tuesday, December 29, 2015 10:12:33 AM
Attachments: [image002.jpg](#)
[image003.gif](#)
[20151228121518960.pdf](#)
[Brent_Sydow.vcf](#)

I have reviewed the attached document and United Power is ok with the proposed setback of the rig.

Thank you



From: Derek Petrie [mailto:derek.petrie@iptenergyservices.com]
Sent: Monday, December 28, 2015 12:39 PM
To: Brent Sydow
Cc: Paul Gottlob
Subject: Powerline Saftey Setback

Brent,

Please review attached documents and contact me with any questions. The COGCC is asking that we confirm through email or letter that the clearance between the rig and powerline is sufficient. The operator (Mendell Finister) has already drilled the eastern most well prior to the rule change with no issue.

In the event that the derrick tipped over we would have 49' of clearance. In the event that the whole rig tipped over there would be over 30' of clearance.

Powerline to Wellhead = 191'
Total Derrick Height= 142'
Total Rig Height = 158.2'

Thanks,
Derek Petrie
Regulatory Supervisor
P: 720-420-5748
M: 307-389-8350
Fax: 720-420-5800

derek.petrie@iptenergyservices.com | www.iptenergyservices.com

cid:image004.gif@01CF7516.038FCDC0



Integrated Petroleum Technologies, Inc. | 1707 Cole Blvd, Suite 200 | Golden, CO 80401

The information contained in this e-mail message (and its attachments) may be privileged, confidential and protected from disclosure. If you are not the intended recipient, please do not read, copy, use, or disclose this communication to others. If you think that you have received this e-mail message in error, please immediately e-mail the sender, then delete this message and any "reply" response from your system. This electronic mail transmission is not intended (and may not be construed or deemed for any purpose) to contain or be an electronic signature.
