

Construction and Stormwater Inspection



Google Earth aerial photo taken 9/7/2013 of the Will Trust 6-62-10 11 CW2 location overview. An area of 7.43 acres was mapped on 1/20/2017 using a Trimble Juno 3B handheld device. Perimeter of the area mapped and highlighted in red.

Construction and Stormwater Inspection



Photo 1. Photo taken from the northwest location, facing East. Insufficient BMP installed around perimeter of location (i.e., swallow ditch) and equipment traffic should be kept off BMPs to ensure they function properly.

Construction and Stormwater Inspection



Photo 2. Photo taken from the northeast location, facing South. Insufficient BMP installed around perimeter of location (i.e., swallow ditch). Equipment traffic should be kept off BMPs to ensure they function properly.

Construction and Stormwater Inspection




Photo 3. Photo taken from the eastern location, facing South. Does not appear a BMP was installed around the eastern spoil stockpile. Spoil stockpile has been tracked and stabilized but that alone is not sufficient to control potential erosion. May suggest marking spoil and topsoil stockpiles to aid in identifying stockpiles for future reference.

Construction and Stormwater Inspection



Photo 4. Photo taken from the northern location, facing West. Insufficient BMP installed around perimeter of location. Topsoil stockpile has been tracked and stabilized but that alone is not sufficient to control potential erosion.

Construction and Stormwater Inspection



Photo 5. Photo taken from the southwest location, facing East. Insufficient BMP installed around perimeter of location. Topsoil stockpile has been tracked and stabilized but that alone is not sufficient to control potential erosion.

Construction and Stormwater Inspection



Photo 6. Photo taken from the southwest location, facing East. Topsoil stockpile has been salvaged and stored along the southern perimeter of location. May suggest marking spoil and topsoil stockpiles to aid in identifying stockpiles for future reference.