

State of Colorado
Oil and Gas Conservation Commission

1120 Lincoln Street, Suite 801, Denver, Colorado 80203 (303) 894-2100 Fax: (303) 894-2109



FOR OGC USE ONLY

Doc# 2227287
Date: 08/09/2017

ACCIDENT REPORT

As required by Rule 602.b.

Report taken by:

DESCRIPTION OF ACCIDENT (Please be as specific as possible)

Name of Operator: <u>Citation Oil & Gas Corp.</u>	Location
Date of Incident: <u>7/30/17</u>	County: <u>Cherokee</u>
Type of Facility (well, tank battery, flow line, pit): <u>Tank Battery</u>	Field Name: <u>Anapahoe Unit</u>
Well Name and Number: <u>Anapahoe Unit Section 9 Tank Bty</u>	QtrQtr: _____ Section: <u>9</u>
API Number: <u>0501706818</u>	Township: <u>14 S</u> Range: <u>42 W</u>
Connect to Accident (land owner, royalty owner, etc.): _____	Meridian: <u>44° 38' 50" N 102° 07' 40" W</u>

Provide a detailed description of the accident, problem, and cause (equipment failure, human error, etc.):

A fire was discovered at the Anapahoe Unit Section 9 Water Tank and Cherokee Wells Fire Dept. Responded to extinguish the fire. The fire was burning from the 1" x 2" hatch & 2" vent riser. Foam was used to extinguish the fire.

Upon investigation it is believed the North Anapahoe Compressor ESD was activated due to the breaker tripping, due to power failure. There was a severe lightning storm just before the incident was reported.

The ESD was reset compressor started and operations resumed to return to normal. The fiberglass tank does not appear to have any damage.

This incident was reported to Stuart Elsworth on 7/31/17 @ 8:48 A.M. on his voicemail. Ext. 5108

OTHER NOTIFICATIONS

List the parties and agencies notified (County, BLM, EPA, DOT, Local Emergency Planning Coordinator or other).

Date	Agency	Contact Person	Response

Accident Tracking No: _____