

From: Dwayne Knudson
To: ["dnr_cogccengineering@state.co.us"](mailto:dnr_cogccengineering@state.co.us)
Cc: mike.longworth@state.co.us; Kellerby - DNR, Shaun; Pake Younger; Matt Honeycutt
Subject: B&V Inspection #689700993 Follow up
Date: Wednesday, February 14, 2018 3:14:00 PM
Attachments: [B&V LOTO Photo 1.pdf](#)
[image001.jpg](#)

Hello,

We recently received an inspection at the subject location with several Corrective Actions (CAs), one of them was to contact the engineering integrity group regarding our plan for resolving the flowline marking CA. The line in question is a fuel supply line for tank heater(s). This line was LOTO and painted per the May 15, 2017 guidance document – see attached photo.

We will begin a field review with the intent to verify all flowlines are either in use, abandoned or properly marked and LOTO per the 5.15.17 guidance document. Any deficiencies will be corrected immediately.

Let us know if there are any questions.

Regards,

Dwayne

Dwayne Knudson

Senior Environmental Specialist



792 Buckhorn Drive

Rifle, CO 81650

Office: (970) 329-4367

Cell: (970) 456-3335

dknudson@ursaresources.com