

State of Colorado  
Oil and Gas Conservation Commission1120 Lincoln Street, Suite 801, Denver, Colorado 80203  
Phone: (303) 894-2100 Fax: (303) 894-2109

OGCC RECEPTION

Receive Date:

03/15/2019

Document Number:

401974935

## Produced Water Transfer System

The Flowline Report, Form 44, shall be submitted to register, report realignment, report removal from service, or report abandonment of Off-Location Flowlines, Produced Water Transfer Systems, Domestic Taps, or Crude Oil Transfer Lines as required by the 1100 Series Rules. The Form shall also be submitted to report Grade 1 Gas Leaks from Flowlines per Rule 1104.k.

## Operator Information

OGCC Operator Number: 10686 Contact Person: Anita Cuevas  
Company Name: NOBLE MIDSTREAM SERVICES LLC Phone: (303) 6537960  
Address: 1625 BROADWAY #2200 Email: anita.cuevas@nblmidstream.com  
City: DENVER State: CO Zip: 80202  
Is the Operator a Tier One member of the Utility Notification Center of Colorado (UNCC) that participates in Colorado's One Call notification system? Yes ☒ No ☐

## PRODUCED WATER TRANSFER SYSTEM

## PRODUCED WATER TRANSFER SYSTEM IDENTIFICATION

Facility ID: 458404 Transfer System Name: MUP-08-TLN-200-L1 Action Type: As Built  
Estimated Daily Transfer Volume: 11000 (barrels) Facility Surety ID: 20180081  
Financial Assurance Rule 711

## PRODUCED WATER TRANSFER SYSTEM REGISTRATION

Planned Construction Date: 09/01/2018

A representative legal location and associated latitude and longitude near the center of the transfer system.

County: WELD  
Qtr Qtr: SESE Section: 25 Township: 3N Range: 65W Meridian: 6  
Latitude: 40.192280 Longitude: -104.621111

## PRODUCED WATER TRANSFER LINE AS-BUILT SPECIFICATIONS

Date Produced Water Transfer Line was Placed into Service: 02/18/2019

## Pipe Description and Testing

Type of Fluid Transferred: Produced Water Pipe Material: Other Standard Dimension Ratio: (for HDPE pipe only)  
Max outer Diameter (inches): 9.120 Wall Thickness: 0.750 Weight (lb/ft): 14.00 Grade:  
Coating: False Pipe Material: Native Materials Burial Depth: 5  
Max Anticipated Operating PSI: 740 Testing Pressure: 1059 Test Date: 01/13/2019

## Description of Corrosion Protection:

N/A

## Description of Integrity Management Program:

A post construction hydrostatic test has been performed and is attached. Continuous pressure monitoring will be implemented within the first year of operation as the integrity method.

Construction method used for all public by-ways, road crossings, sensitive wildlife habitats, sensitive areas and natural and manmade watercourses (i.e., bored and cased or bored only)

Open cut for private access roads. No other crossings.

#### OPERATOR COMMENTS AND SUBMITTAL

Comments Facility 458404 was originally named DP 408 E PW. The pipeline name has changed to MUP-08-TLN-200-L1. Pipe grade is 750 psi.

I hereby certify that the statements made in this form are, to the best of my knowledge, true, correct and complete.  
Signed: \_\_\_\_\_ Date: 03/15/2019 Email: anita.cuevas@nblmidstream.com

Print Name: Anita Cuevas Title: Regulatory Contractor

Based on the information provided herein, this Flowline Report complies with COGCC Rules and applicable orders and is hereby approved.

COGCC Approved: \_\_\_\_\_

Director of COGCC

Date: 5/30/2019

#### Attachment Check List

<u>Att Doc Num</u>	<u>Name</u>
401974935	Form44 Submitted
401974943	AFFIDAVIT OF COMPLETION
401974944	PRESSURE TEST
401974945	PRODUCED WATER TRANSFER SYSTEM GEODATABASE GDB
401974946	PRODUCED WATER TRANSFER SYSTEM LAYOUT DRAWING
401974947	LEAK PROTECTION AND MONITORING PLAN

Total Attach: 6 Files