

	Chassis	Lower Module	Upper Module	BARO Module	Left Scale	Right Scale
Serial Number	479180	477666			477666	
Model	NV	3KPSI				
Message Store						
Userspan		1.00000				
Offset						
Datatype					Lower	
Units		PSI G			PSI G	
Tare						
Average						
User Factor						
User Offset						
User Resolution						
Firmware Version	R080016	R090009				
Calibration Due		16-Jun-18				
Run Index	0					
Run Start Time				11-Jul-19/15:53:00		
Run Duration				23 minutes 15 seconds		
Run Tag				Tag 1 fed 4-22		
Logging Interval	15.0					

Data Points		
Point #	Time	Left - PSI G

1	00:00:00.0	0.3
2	00:00:15.0	0.3
3	00:00:30.0	0.9
4	00:00:45.0	4.6
5	00:01:00.0	10.9
6	00:01:15.0	25.3
7	00:01:30.0	78.9
8	00:01:45.0	295.2
9	00:02:00.0	413.3
10	00:02:15.0	406.8

11	00:02:30.0	401.7
12	00:02:45.0	400.1
13	00:03:00.0	399.5
14	00:03:15.0	399.1
15	00:03:30.0	398.5
16	00:03:45.0	398.1
17	00:04:00.0	397.7
18	00:04:15.0	397.3
19	00:04:30.0	397.0
20	00:04:45.0	396.7
21	00:05:00.0	396.3
22	00:05:15.0	396.1
23	00:05:30.0	395.9
24	00:05:45.0	395.6
25	00:06:00.0	395.4
26	00:06:15.0	395.0
27	00:06:30.0	394.9
28	00:06:45.0	394.6
29	00:07:00.0	394.4
30	00:07:15.0	394.1
31	00:07:30.0	393.9
32	00:07:45.0	393.7
33	00:08:00.0	393.4
34	00:08:15.0	393.2
35	00:08:30.0	393.0
36	00:08:45.0	392.8
37	00:09:00.0	392.5
38	00:09:15.0	392.3
39	00:09:30.0	392.2
40	00:09:45.0	393.1
41	00:10:00.0	392.9
42	00:10:15.0	392.8
43	00:10:30.0	392.6
44	00:10:45.0	392.4
45	00:11:00.0	392.2
46	00:11:15.0	392.1
47	00:11:30.0	391.9

48	00:11:45.0	391.8
49	00:12:00.0	391.6
50	00:12:15.0	391.5
51	00:12:30.0	391.3
52	00:12:45.0	391.1
53	00:13:00.0	390.9
54	00:13:15.0	390.7
55	00:13:30.0	390.4
56	00:13:45.0	390.2
57	00:14:00.0	390.0
58	00:14:15.0	389.8
59	00:14:30.0	389.7
60	00:14:45.0	389.5
61	00:15:00.0	389.4
62	00:15:15.0	389.2
63	00:15:30.0	389.0
64	00:15:45.0	389.8
65	00:16:00.0	389.4
66	00:16:15.0	389.3
67	00:16:30.0	389.2
68	00:16:45.0	389.1
69	00:17:00.0	389.1
70	00:17:15.0	389.1
71	00:17:30.0	389.3
72	00:17:45.0	389.3
73	00:18:00.0	389.3
74	00:18:15.0	389.3
75	00:18:30.0	389.2
76	00:18:45.0	389.0
77	00:19:00.0	389.0
78	00:19:15.0	388.9
79	00:19:30.0	389.0
80	00:19:45.0	389.0
81	00:20:00.0	389.0
82	00:20:15.0	389.0
83	00:20:30.0	388.9
84	00:20:45.0	388.9

85	00:21:00.0	388.9
86	00:21:15.0	388.8
87	00:21:30.0	388.8
88	00:21:45.0	388.9
89	00:22:00.0	388.9
90	00:22:15.0	388.8
91	00:22:30.0	388.9
92	00:22:45.0	286.1
93	00:23:00.0	4.6
94	00:23:15.0	0.0