

A Pots & Pans

FOUNDATION ENERGY - Operations

D

CATALYTIC HEATER SAFETY

V

Recently we had an incident involving a catalytic heater inside a meter shed starting a fire. We determined that the regulator was washed out letting too much gas into the heater which found and ignition source!

I

Before lighting a heater always check the atmosphere with a LEL monitor and check for any visible ignition sources.

S

It is always important to remove the gas line and check the flow of gas going to the heater. This can be done with a simple oz gauge.

O

Most important, always hook up power leads inside the building first and then hook them up to your battery outside the building last. When possible come back asap and check the heater.

R

Y

