

Chris Hohnstein

From: Brian Ulmer
Sent: Thursday, June 20, 2019 2:17 PM
To: Chris Hohnstein; Kevin Monaghan
Subject: FW: EXTERNAL: Re: BB Draw H04-06JI (05-123-20531) P&A change

Brian Ulmer
Noble Energy
Office – 720-587-2307
Mobile – 303-905-4467

From: Jacobson - DNR, Eric <eric.jacobson@state.co.us>
Sent: Thursday, June 20, 2019 2:12 PM
To: Brian Ulmer <Brian.Ulmer@nbenergy.com>
Subject: EXTERNAL: Re: BB Draw H04-06JI (05-123-20531) P&A change

Brian

Approved as outlined.

Eric

On Thu, Jun 20, 2019 at 2:09 PM Brian Ulmer <Brian.Ulmer@nbenergy.com> wrote:

Eric,

-

We will punch tubing at 5610' and we wanted to know if you would be ok if we pump a 80 sks plug from 5610' to 4014' (top of proposed Sussex plug) and then we will pressure test that plug to make sure it holds pressure prior to continuing on.

-

Let me know if you approve this plan.

-

Thanks!

-

Brian Ulmer

Noble Energy

Office – 720-587-2307


Mobile – 303-905-4467

-

--

Eric Jacobson, PE

Engineer



303-894-2100 (5265)

1120 N Lincoln St Ste 801, Denver, CO 80203

Chris Hohnstein

From: Brian Ulmer
Sent: Thursday, June 20, 2019 2:20 PM
To: Chris Hohnstein
Cc: Kevin Monaghan
Subject: BB Draw H04-06JI plan forward

Chris,

Here is the plan forward. Let me know if I missed something.

Thanks!

- 1 RIH with cast iron tubing plug and set at 5700'.
- 2 Load tubing and pressure test to 500 psi.
- 2 RIH and shoot tubing punch at 5610'.
- 3 Establish circulation and good returns
- 4 Pump 115 sks of Gneat cement from 5610' to 4014'.

Length (ft)	OD (in)	ID (in)	ft ³ /ft	Volume (ft ³)	Yield (ft ³ /sk)	Cement (s)
1596	4.000	2.375	0.057	90	1.150	78
1596	2.000	0.000	0.022	35	1.150	30
						TOTAL:

- 5 Displace with 15 bbls for balanced plug.

Tubing ID	Length (ft)	Disp. (BBL/ft)	Disp (BBL)
2	4014	0.00389	15.6

- 6 SI well overnight.
- 7 Pressure test casing to 500 psi for 15 minutes. If pressure does not hold call supervisor/engineer for plan forward
- 8 Continue with P&A as planned.

Brian Ulmer
Noble Energy
Office – 720-587-2307
Mobile – 303-905-4467

Chris Hohnstein

From: Brian Ulmer
Sent: Friday, June 21, 2019 11:20 AM
To: Chris Hohnstein; Eric Peterson (Contractor); Kevin Monaghan
Subject: FW: EXTERNAL: Re: BB Draw H04-06JI (05-123-20531) P&A change

Brian Ulmer
Noble Energy
Office – 720-587-2307
Mobile – 303-905-4467

From: Jacobson - DNR, Eric <eric.jacobson@state.co.us>
Sent: Friday, June 21, 2019 11:18 AM
To: Brian Ulmer <Brian.Ulmer@nblenergy.com>
Subject: EXTERNAL: Re: BB Draw H04-06JI (05-123-20531) P&A change

Brian

Approved as outlined.

Eric

On Fri, Jun 21, 2019 at 10:56 AM Brian Ulmer <Brian.Ulmer@nblenergy.com> wrote:

Eric,

-

After we pumped the plug from 5610 – 4014 the casing held pressure but we discovered a hole in tubing at around 2112'.

-

My proposal is to move the courtesy plug up to 2100' to 1600'.

-

Please let me know if you approve this plan.

-

-

Thanks!

-

Brian Ulmer

Noble Energy

Office – 720-587-2307

Mobile – 303-905-4467

-

From: Brian Ulmer

Sent: Thursday, June 20, 2019 2:21 PM

To: Jacobson - DNR, Eric <eric.jacobson@state.co.us>

Subject: RE: EXTERNAL: Re: BB Draw H04-06JI (05-123-20531) P&A change

-

Thank you sir!

-

Brian Ulmer

Noble Energy

Office – 720-587-2307

Mobile – 303-905-4467

-

From: Jacobson - DNR, Eric <eric.jacobson@state.co.us>

Sent: Thursday, June 20, 2019 2:12 PM

To: Brian Ulmer <Brian.Ulmer@nblenergy.com>

Subject: EXTERNAL: Re: BB Draw H04-06JI (05-123-20531) P&A change

-

Brian

-

Approved as outlined.

-

Eric

-

On Thu, Jun 20, 2019 at 2:09 PM Brian Ulmer <Brian.Ulmer@nblenergy.com> wrote:

Eric,

-

We will punch tubing at 5610' and we wanted to know if you would be ok if we pump a 80 sks plug from 5610' to 4014' (top of proposed Sussex plug) and then we will pressure test that plug to make sure it holds pressure prior to continuing on.

-

Let me know if you approve this plan.

-

Thanks!

-

Brian Ulmer

Noble Energy

Office – 720-587-2307


Mobile – 303-905-4467

-

=

Eric Jacobson, PE

Engineer



303-894-2100 (5265)

1120 N Lincoln St Ste 801, Denver, CO 80203

=

Eric Jacobson, PE

Engineer



303-894-2100 (5265)

1120 N Lincoln St Ste 801, Denver, CO 80203