

**FORM
INSP**

Rev
X/15

**State of Colorado
Oil and Gas Conservation Commission**

1120 Lincoln Street, Suite 801, Denver, Colorado 80203
Phone: (303) 894-2100 Fax: (303) 894-2109



Inspection Date:

02/24/2020

Submitted Date:

03/04/2020

Document Number:

699800631

FIELD INSPECTION FORM

Loc ID 334515 Inspector Name: De Paolo, Corey On-Site Inspection 2A Doc Num: _____

Status Summary:

- THIS IS A FOLLOW UP INSPECTION
- FOLLOW UP INSPECTION REQUIRED
- NO FOLLOW UP INSPECTION REQUIRED

Operator Information:

OGCC Operator Number: 10433
Name of Operator: LARAMIE ENERGY LLC
Address: 1401 SEVENTEENTH STREET #1401
City: DENVER State: CO Zip: 80202

Findings:

3 Number of Comments
0 Number of Corrective Actions
 Corrective Action Response Requested

ANY CORRECTIVE ACTION(S) FROM PREVIOUS INSPECTIONS THAT HAVE NOT BEEN ADDRESSED ARE STILL APPLICABLE

Contact Information:

Contact Name	Phone	Email	Comment
, Laramie		cogccnotifications@laramie-energy.com	
Kellerby, Shaun		shaun.kellerby@state.co.us	

Inspected Facilities:

Facility ID	Type	Status	Status Date	Well Class	API Num	Facility Name	Insp Status
455944	Domestic Tap	AC	07/12/2018		-	Domestic Tap 18-12 Pad	AC

General Comment:

[COGCC Inspection Report Summary](#)
On Monday 2/24/20 at approximately 13:00 hours, I, Inspector Corey De Paolo, Conducted a domestic tap inspection at LARAMIE ENERGY LLC Domestic Tap /18-12 Pad, Location #455944 in Mesa County Colorado.
Refer to location #334515 for inventory, inspections and all other documents.
The domestic tap is derived from the back side casing master valve of the Campbell 18-13 wellhead API #05-077-08993. See photo #0629. The pressure is regulated with a 1" Fisher type 630 regulator. The regulator has a maximum pressure drop of 1500 psi and a maximum outlet pressure of 30 psi. The operational pressure range of this regulator is 7 to 30 psi. See photo #0630. The piping upstream of the regulator is built with what appears to be 1000 or 2000 psi rated threaded fittings and has a 1" Balon valve for isolation. Downstream of the regulator there is a 1" WKM valve for isolation. The piping is built with railroad unions and cast fittings which appear to be sufficient to support the maximum outlet pressure of 30 psi. See photo #0628. The only form of fluid control and or fluid separation is a torpedo scrubber located down-stream of the regulator. See photo #0631. This domestic tap supplies service to the house South West of location with an address of 60517 LE Rd Colbran CO 81624. Refer to document #401672897 for point of origin and point of delivery.
This is a summary of inspection report.

Location

Lease Road:			
Type	Access		
comment:			
Corrective ActionL			Date:

Overall Good:

Signs/Marker:			
Type	WELLHEAD		
Comment:			
Corrective Action:			Date:

Emergency Contact Number:			
Comment:	Operators battery sign 911. Numbers listed on domestic tap sgin at wellhead 970-487-3266, 970-640-9457, 970-640-4909		
Corrective Action:			Date:

Overall Good:

Spills:			
Type	Area	Volume	

In Containment: No

Comment:

Multiple Spills and Releases?

Venting:			
Yes/No	NO		
Comment:			
Corrective Action:			Date:

Flaring:			
Type			
Comment:			
Corrective Action:			Date:

Inspected Facilities

Facility ID: 455944 Type: Domestic Tap API Number: - Status: AC Insp. Status: AC

Producing Well

Comment: Producing

Corrective Action:

Date:

Attached Documents

You can go to COGCC Images (<https://cogcc.state.co.us/weblink/>) and search by document number:

Document Num	Description	URL
699800632	Photos for Insp. #699800631	http://ogccweblink.state.co.us/DownloadDocumentPDF.aspx?DocumentId=5085879