

Flowline Integrity Testing Log

Well Name: U.P. Sabin, Martinez #1, Martinez #3 Date: 9/27/2018

Flowing Well: _____ Pumping Well:

API Number: _____

Operator: Prospect Energy

General Weather Conditions: (Circle applicable) Windy Cloudy Sunny
<70F >70F Rain Snow Calm

Test Start Time: 4:00 pm Test Stop Time: 4:15 pm
 Test Start Pressure: 41# Test End Pressure: 41#

Integrity Issue Found Yes: _____ No:
 *if yes indicate issue found in notes below


Testing Log

Time	Pressure
0:00	41#
0:05	41#
0:10	41#
0:15	41#

Notes:

Test U.P. Sabin, Mart. #1, Mart. #3 gas lines to Martinez Battery culvert
 2" poly gasline, normal pressure 5#

Tested by: Mike Staab, Miles Gracey



Graphic Controls Inc
L.P. Sabin,
Martinez #1, Martinez #3 Gas line
CHART NO. MC MP-250-150F

METER _____
TAKEN OFF _____
M
CHART PUT ON _____
M
LOCATION _____
REMARKS _____

9/27/2018

Normal Pressure

400 Test

150 Test