


## Data Collection Report

	Chassis	Left Scale	Right Scale
Serial Number	256427	460696	258199
Datatype		Lower	Upper
Units		PSI G	°F





7200 E. Dry Creek Rd. C-102  
Centennial, Co. 80112  
303-804-0667

[cal.lab@apex-instruments.com](mailto:cal.lab@apex-instruments.com)

Silverline Services  
1287 Diamond Drive  
Windsor, CO 80550

Page 1

### CALIBRATION CERTIFICATE: 6359

Jan 6 2015

Device Information:	DUT	Reference
Model	nVision	RPM4-E-DWT
Manufacturer	Crystal Engineering	DH Instruments
Serial Number	460696	1709
Pressure Range	0.000 to 10000.000	0.000 to 10000.000
Tolerance	0.03 %FS + 0.1 %Rdg	0.01 %Span
Data Acquisition Mode	RS232	RS232
Date of Calibration	Jan 6 2015	Oct 10 2014
Calibration Due	Jan 6 2016	Oct 10 2015

Test Information	Conditions
Test Table	Ambient Pressure
Date	Ambient Temperature
Time	Ambient Relative Humidity
Operator	23° +/- 3.0° C
Station ID	20% - 60%
Mark	

### As Received Data:

Test Point	Reference Pressure	DUT Pressure	DUT Raw Output	Abs. Error	% Span Error	DUT Tolerance	Status
	psi	psi	psi	psi	%	psi	
1	0	0.000	0.000	0.000	0.0000	3.000	Pass
2	2028	2027.716	2027.716	-0.284	-0.0023	5.028	Pass
3	4017	4015.989	4015.989	-1.011	-0.0054	7.016	Pass
4	6040	6039.126	6039.126	-0.874	-0.0046	9.039	Pass
5	8011	8009.598	8009.598	-1.402	-0.0112	11.010	Pass
6	10023	10022.479	10022.479	-0.521	-0.0099	13.022	Pass
7	7979	7977.785	7977.785	-1.215	-0.0151	10.978	Pass
8	6019	6018.186	6018.186	-0.814	-0.0087	9.018	Pass
9	4035	4034.712	4034.712	-0.288	-0.0029	7.035	Pass
10	2050	2049.439	2049.439	-0.561	-0.0027	5.049	Pass
11	0	0.000	0.000	0.000	0.0000	3.000	Pass

As Received First Order Fit:  $y = 1.000102E00x + 1.691025E-01$


### As Left Data:

Test Point	Reference Pressure	DUT Pressure	DUT Raw Output	Abs. Error	% Span Error	DUT Tolerance	Status
	psi	psi	psi	psi	%	psi	
1	0	0.000	0.000	0.000	0.0000	3.000	Pass

2	2028	2027.716	2027.716	-0.284	-0.0023	5.028	Pass
3	4017	4015.989	4015.989	-1.011	-0.0054	7.016	Pass
4	6040	6039.126	6039.126	-0.874	-0.0046	9.039	Pass
5	8011	8009.598	8009.598	-1.402	-0.0112	11.010	Pass
6	10023	10022.479	10022.479	-0.521	-0.0099	13.022	Pass
7	7979	7977.785	7977.785	-1.215	-0.0151	10.978	Pass
8	6019	6018.186	6018.186	-0.814	-0.0087	9.018	Pass
9	4035	4034.712	4034.712	-0.288	-0.0029	7.036	Pass
10	2050	2049.439	2049.439	-0.561	-0.0027	6.049	Pass
11	0	0.000	0.000	0.000	0.0000	3.000	Pass

As Left First Order Fit:  $y = 1.000102E00x + 1.691025E-01$

Page 2



This calibration report shall not be reproduced, except in full, without the written approval of the issuer.

  
APEX Technician - Mark Hutchison


This Instrument has been calibrated using standards with accuracies traceable to the National Institute of Standards and Technology, derived from natural physical constants, derived from ratio measurements or compared consensus standards.

PERMIT CROSSINGS	
LOCATION	QUANTITY
DITCH	0
RIVER	0
COUNTY ROAD	0
HIGHWAY	0
RAILROAD	0
OVERHEAD ELECTRICAL	1

PIPE QUANTITIES						
TYPE	SERVICE	OD	WT	GR	LF	COATING
Pipeline	Liquid	8.625"	0.322"	X-42	19,800'	FBE 12-14 MIL

Above Ground

~~Below~~ Below Ground



KEY	
---	NEW
- - - - -	FUTURE
- - - - -	EXISTING
- - - - -	SITE LIMITS
- - - - -	ROAD/HIGHWAY
	RAILROAD
~~~~~	DITCH/CANAL/RIVER
XX'	BORE LENGTH

PRELIMINARY

DWG NO.	REFERENCE DRAWINGS DESCRIPTION	REVISIONS										APPROVALS			WELL RANCH GATHERING SYSTEM DP104 OPERATIONAL SCHEMATIC
		ISSUED FOR REVIEW	REV	BY	DATE	CHK BY	CHK DATE	APR BY	APR DATE	PROJ. NGR.	SIGNATURE	DATE			