

State of Colorado
Oil and Gas Conservation Commission

1120 Lincoln Street, Suite 801, Denver, Colorado 80203
Phone: (303) 894-2100 Fax: (303) 894-2109



Document Number:

402463185

Date Received:

08/10/2020

FIR RESOLUTION FORM

Overall Status: CAC

CA Summary:

3 of 5 CAs from the FIR responded to on this Form

3 CA Completed
0 Factual Review Request

OPERATOR INFORMATION

OGCC Operator Number: 10000

Name of Operator: BP AMERICA PRODUCTION COMPANY

Address: 1199 MAIN AVENUE SUITE 101

City: DURANGO State: CO Zip: 81301

Contact Name and Telephone:

Name: _____

Phone: () _____ Fax: () _____

Email: _____

Additional Operator Contact:

Contact Name	Phone	Email
<u>Inspections, All</u>		<u>SanJuanCOGCC@bp.com</u>
<u>Beebe, Sabre</u>	<u>970-779-9398</u>	<u>Sabre.Beebe@bpx.com</u>
<u>Fischer, Alex</u>		<u>alex.fischer@state.co.us</u>
<u>Heil, John</u>		<u>john.heil@state.co.us</u>

COGCC INSPECTION SUMMARY:

FIR Document Number: 688800748

Inspection Date: 07/08/2020

FIR Submit Date: 07/08/2020

FIR Status: _____

Inspected Operator Information:

Company Name: BP AMERICA PRODUCTION COMPANY

Company Number: 10000

Address: 1199 MAIN AVENUE SUITE 101

City: DURANGO State: CO Zip: 81301

LOCATION - Location ID: _____

Location Name: _____ Number: _____ County: _____

Qtrqtr: SENW Sec: 16 Twp: 34N Range: 9W Meridian: M

Latitude: 37.194643 Longitude: -107.834841

FACILITY - API Number: 05-067- -00 Facility ID: 477145

Facility Name: Craig 1 Number: _____

Qtrqtr: SENW Sec: 16 Twp: 34N Range: 9W Meridian: M

Latitude: 37.194643 Longitude: -107.834841

CORRECTIVE ACTIONS:

1 ☒ CA# 140328

Corrective Action: Secondary containment is inadequate to contain largest single tank plus sufficient freeboard.

Date: 08/07/2020

Response: CA COMPLETED

Date of Completion: 08/10/2020

Secondary containment berm constructed around tank see previously submitted FIRR 40245815 submitted

Operator
Comment:

COGCC Decision: Approved pending re-inspection

COGCC
Representative:

2 ☒ CA# 140329

Corrective Action: Install sign to comply with Rule 210.d.

Date: 09/08/2020

Response: CA COMPLETED

Date of Completion: 08/06/2020

Operator
Comment:

Newly purchased sign installed for the tank see attached.

COGCC Decision: Approved via an AMI

COGCC
Representative:

4 ☒ CA# 140331

Corrective Action: Control and contain spills/releases and clean up per Rule 906.a. Contact COGCC EPS staff.

Date: 08/07/2020

Response: CA COMPLETED

Date of Completion: 08/10/2020

Operator
Comment:

Please refer to document #402447891 for spill actions on control and containment of spill. See previously submitted FIRR #40245815

COGCC Decision: Approved pending re-inspection

COGCC
Representative:

OPERATOR COMMENT AND SUBMITTAL

Comment: Corrective actions completed

I hereby certify that the statements made in this form are, to the best of my knowledge, true, correct, and complete.

Print Name: Sabre Beebe

Signed: _____

Title: Specialist

Date: 8/10/2020 2:19:47 PM

ATTACHMENT LIST

View Attachments in Imaged Documents on COGCC website (<http://ogccweblink.state.co.us/>) - Search by Document Number.

<u>Document Number</u>	<u>Description</u>
402463185	FIR RESOLUTION SUBMITTED
402463198	New tank sign installation

Total Attach: 2 Files