

State of Colorado
Oil and Gas Conservation Commission

1120 Lincoln Street, Suite 801, Denver, Colorado 80203
Phone: (303) 894-2100 Fax: (303) 894-2109



Document Number:
402523352

Date Received:
11/02/2020

FIR RESOLUTION FORM

Overall Status: CAC

CA Summary:

1 of 1 CAs from the FIR responded to on this Form

1 CA Completed
0 Factual Review Request

OPERATOR INFORMATION

OGCC Operator Number: 69175

Name of Operator: PDC ENERGY INC

Address: 1775 SHERMAN STREET - STE 3000

City: DENVER State: CO Zip: 80203

Contact Name and Telephone:

Name: _____

Phone: () _____ Fax: () _____

Email: _____

Additional Operator Contact:

Contact Name

Phone

Email

Tyranny Bergin

970-313-5547

EHSCOGCCInspections@pdce.com

COGCC INSPECTION SUMMARY:

FIR Document Number: 697002252

Inspection Date: 10/20/2020

FIR Submit Date: 10/20/2020

FIR Status: _____

Inspected Operator Information:

Company Name: PDC ENERGY INC

Company Number: 69175

Address: 1775 SHERMAN STREET - STE 3000

City: DENVER State: CO Zip: 80203

LOCATION - Location ID: 332804

Location Name: Frank Number: 21-7B County: WELD

Qtrqr: NWN Sec: 32 Twp: 4N Range: 66W Meridian: 6
W

Latitude: 40.274167 Longitude: -104.807780

FACILITY - API Number: 05-123-00 Facility ID: 279295

Facility Name: FRANK Number: 5

Qtrqr: NWN Sec: 32 Twp: 4N Range: 66W Meridian: 6
W

Latitude: 40.274167 Longitude: -104.807780

CORRECTIVE ACTIONS:

1 CA# 142823

Corrective Action: Repair or install berms or other secondary containment devices per Rule 605.a.(4).

Date: 12/24/2020

Response: CA COMPLETED

Date of Completion: 11/02/2020

Operator Comment: PDC conducted an annual SPCC inspection on May 12, 2020, it was determined the tank battery berm was in compliance with both Federal and State Rules/Regulations. The current tank battery berm dimensions demonstrate there is 105% total capacity including precipitation, which is above Federal and State requirements for this production facility. The COGCC inspection did not provide details on the non-compliance determination, such as berm dimensions and measurement points/methods. See the attached SPCC inspection calculations

and Site-Specific SPCC plan.

COGCC Decision: _____

COGCC
Representative:

OPERATOR COMMENT AND SUBMITTAL

Comment: PDC conducted an annual SPCC inspection on May 12, 2020, it was determined the tank battery berm was in compliance with both Federal and State Rules/Regulations. The current tank battery berm dimensions demonstrate there is 105% total capacity including precipitation, which is above Federal and State requirements for this production facility. The COGCC inspection did not provide details on the non-compliance determination, such as berm dimensions and measurement points/methods. See the attached SPCC inspection calculations and Site-Specific SPCC plan.

I hereby certify that the statements made in this form are, to the best of my knowledge, true, correct, and complete.

Print Name: Tyranny Bergin

Signed: _____

Title: EHS Coordinator

Date: 11/2/2020 10:04:01 AM

ATTACHMENT LIST

View Attachments in Imaged Documents on COGCC website (<http://ogccweblink.state.co.us/>) - Search by Document Number.

Document Number	Description
402523356	Attachment #1 - Frank 5
402523359	Attachment #2 - Frank 5

Total Attach: 2 Files