

From: [Bob Beecherl](#)
To: ["Melvin Geib Inc"](#)
Subject: RE: Pad Construction Bid
Date: Wednesday, October 2, 2019 10:46:00 AM
Attachments: [image001.png](#)

See my answers in Red.

All pad questions:

- 1) Can you provide the depth for topsoil stripping? **Mike Cugnetti is on his way out there now to take top soil estimates. I'll let you know asap. I think we are assuming 6" for now.**
- 2) Do you have volumes available along with the grading plans, or are you wanting contractors to do our own takeoffs? **I just sent the cut and fills. The sonic stay was on the original attachments, but I just sent the other 3. Let me know if you were asking for something else.**
- 3) I do not see any details for Stormwater BMP's (are you wanting us to make assumptions on sediment traps and perimeter ditch & berm, etc?) **All pads will have ditch and berm installed as first cut of pad build. Most pads will have two sediment traps built at the ditch corners on the lower drainage side of each pad. Ditch and berms must be well compacted. Sediment traps will be 15'x30'x4' with riprap armored inlets and outlets. Sediment trap outlets will also have waddles installed. Culverts will be installed at access road as needed.**
Weld county is installing new requirements for this as we speak. This may change in the next couple of weeks. The above statement is our best guest right now.
- 4) Do you want me to include pricing for the fencing on all pads? If so, can you please give me details? (electric, 3-wire cattle, etc) **Fencing and cattleguards will be done after completion.**

I will be available in the office all day tomorrow (8:30 - 5:30pm) so feel free to call and chat.

Thanks!

Becky Ball,
Office Manager, Melvin Geib Inc.
970-834-2298 (office)
970-834-1157 (fax)

-----Original Message-----

From: Bob Beecherl <BBeecherl@VerdadOil.com>
To: Melvin Geib Inc <melvingeibinc@aol.com>
Sent: Thu, Sep 19, 2019 12:45 pm
Subject: RE: Pad Construction Bid

Yes. I just got back to the office so feel free to give me a call

From: Melvin Geib Inc <melvingeibinc@aol.com>
Sent: Thursday, September 19, 2019 11:58 AM
To: Bob Beecherl <BBeecherl@VerdadOil.com>
Subject: Re: Pad Construction Bid

Bob,

Thank you for these grading plans. Do you have a time available this afternoon for a quick call to discuss any questions I might have?

Regards,,

Becky Ball,
Office Manager, Melvin Geib Inc.
970-834-2298 (office)
970-834-1157 (fax)