

**FORM  
INSP**

Rev  
X/20

**State of Colorado  
Oil and Gas Conservation Commission**

1120 Lincoln Street, Suite 801, Denver, Colorado 80203  
Phone: (303) 894-2100 Fax: (303) 894-2109



Inspection Date:

11/11/2021

Submitted Date:

11/11/2021

Document Number:

699503339

**FIELD INSPECTION FORM**

Loc ID 319943 Inspector Name: MEDINA, JUSTIN On-Site Inspection  2A Doc Num: \_\_\_\_\_

**Operator Information:**

OGCC Operator Number: 70385  
Name of Operator: SMITH ENERGY CORP  
Address: 12706 SHILOH RD  
City: GREELEY State: CO Zip: 80631

**Status Summary:**

- THIS IS A FOLLOW UP INSPECTION
- FOLLOW UP INSPECTION REQUIRED
- NO FOLLOW UP INSPECTION REQUIRED

**Findings:**

- 15 Number of Comments
- 4 Number of Corrective Actions
- Corrective Action Response Requested

**ANY CORRECTIVE ACTION(S) FROM PREVIOUS INSPECTIONS THAT HAVE NOT BEEN ADDRESSED ARE STILL APPLICABLE**

**Contact Information:**

Contact Name	Phone	Email	Comment
Smith, Chris	(303) 709-6157/ (970) 799-3899	smithenergy@live.com	
Smith, Glenn	(970) 381-6253	gsmithten@what-wire.com	<a href="#">All Inspections</a>

**Inspected Facilities:**

Facility ID	Type	Status	Status Date	Well Class	API Num	Facility Name	Insp Status
201961	WELL	SI	06/01/2018	GW	001-07365	ROBIN LYNN 1	SI

**General Comment:**

*(This area is intentionally left blank for general comments.)*

Location			
Overall Good: <input checked="" type="checkbox"/>			
<b>Signs/Marker:</b>			
Type	OTHER		
Comment:	Unable to inspect signage on site due to weed growth on location		
Corrective Action:			Date:
Emergency Contact Number:			
Comment:	<input style="width: 100%;" type="text"/>		
Corrective Action:	<input style="width: 100%;" type="text"/>		Date: _____
<b>Good Housekeeping:</b>			
Type	WEEDS		
Comment:	Weeds unmanaged on location		
Corrective Action:	Comply with COGCC housekeeping rules		Date: <u>12/11/2020</u>
Type	OTHER		
Comment:	Berms on location need to be repaired.		
Corrective Action:	on: Inadequate berms around tank(s) Repair or install berms or other secondary containment devices per Rule 605.a.(4). Corrective Action Date 12/11/2020 days. See attached photos		Date: <u>12/11/2020</u>
Overall Good: <input type="checkbox"/>			
<b>Spills:</b>			
Type	Area	Volume	
In Containment: No			
Comment:	<input style="width: 100%;" type="text"/>		
<input type="checkbox"/> Multiple Spills and Releases?			
<b>Equipment:</b>			
Type: Bradenhead	# 1	corrective date	
Comment:	Unable to inspect due to weed growth on location		
Corrective Action:			Date:
Type: Deadman # & Marked	# 4		
Comment:	Marked with steel fence post		
Corrective Action:			Date:
Type: Bird Protectors	# 1		
Comment:			
Corrective Action:			Date:
Type: Plunger Lift	# 1		
Comment:			
Corrective Action:			Date:
Type: Horizontal Heated Separator	# 1		
Comment:			
Corrective Action:			Date:

Type: Vertical Separator	# 1		
Comment:			
Corrective Action:			Date:

**Tanks and Berms:**

Contents	#	Capacity	Type	Tank ID	SE GPS
PRODUCED WATER	1	200 BBLs	PBV STEEL		,
Comment:	210 BBL				
Corrective Action:					Date:

**Paint**

Condition	Adequate	
Other (Content)		
Other (Capacity)		
Other (Type)		

**Berms**

Type	Capacity	Permeability (Wall)	Permeability (Base)	Maintenance
Comment:	shares containment with oil tank			
Corrective Action:				Date:

Contents	#	Capacity	Type	Tank ID	SE GPS
CRUDE OIL	1	200 BBLs	STEEL AST		,
Comment:	210 BBL				
Corrective Action:					Date:

**Paint**

Condition	Adequate	
Other (Content)		
Other (Capacity)		
Other (Type)		

**Berms**

Type	Capacity	Permeability (Wall)	Permeability (Base)	Maintenance
Comment:	Unable to inspect due to weed growth, corrective action from previous inspection			
Corrective Action:				Date:

Contents	#	Capacity	Type	Tank ID	SE GPS
PRODUCED WATER	1	100 BBLs	Open Top		,
Comment:	Netting adequate				
Corrective Action:					Date:

**Paint**

Condition		
Other (Content)		
Other (Capacity)		

Other (Type) _____				
<b>Berms</b>				
Type	Capacity	Permeability (Wall)	Permeability (Base)	Maintenance
Comment: <span style="color: blue;">shares containment with oil tank</span>				
Corrective Action: _____				Date: _____
<b>Venting:</b>				
	Yes/No	NO		
Comment: _____				
Corrective Action: _____				Date: _____
<b>Flaring:</b>				
Type				
Comment: _____				
Corrective Action: _____				Date: _____

**Inspected Facilities**

Facility ID: 201961 Type: WELL API Number: 001-07365 Status: SI Insp. Status: SI

**Idle Well**

Purpose:  Shut In  Temporarily Abandoned Reminder: \_\_\_\_\_

Comment: Well has been shut in since 6/1/18, missing production logs from 10/1/19 to present. Well is in need of mechanical integrity test. Contact COGCC engineering.

Corrective Action: Comply with COGCC MIT rules for shut in wells. Date: 11/10/2021

**BradenHead**

Date of Last Brhd Test: \_\_\_\_\_ Annual Brhd Completed? No

Last Brhd Test Results Initial Surf Csg Pressure: \_\_\_\_\_ Fluid Type: \_\_\_\_\_

End Surf Csg Pressure: \_\_\_\_\_

Comment: No bradenhead test is on file. Bradenhead test is delinquent. Contact COGCC engineering. Provide monthly monitoring data. 11/21/2021

Corrective Action: Comply with COGCC annual bradenhead testing rules. Date: \_\_\_\_\_

**COGCC Comments**

Comment	User	Date
<p>COGCC Inspection Report Summary                      On 11/10/21 at approximately 1430 I, Inspector Justin Medina conducted an on-site inspection at:                      Well Name- Robin Lynn 1                      Company Name- Smith Energy Corp                      API- 05-001-07365                      In Adams County Colorado.                      While there, I observed SI well                      This is a follow up inspection from document # 700900331 Corrective Actions are Delinquent                      During this inspection the following possible compliance issues were observed:                      No bradenhead test is on file. Bradenhead test is delinquent. Contact COGCC engineering. Provide monthly monitoring data.                      Comply with COGCC annual bradenhead testing rules. 11/21/21                      Well has been shut in since 6/1/18, missing production logs from 10/1/19 to present. Well is in need of mechanical integrity test. Contact COGCC engineering.                      Comply with COGCC MIT rules for shut in wells.11/10/21                      Berms on location need to be repaired.                      on: Inadequate berms around tank(s) Repair or install berms or other secondary containment devices per Rule 605.a.(4). Corrective Action Date 12/11/2020 days. See attached photos                      Weeds unmanaged on location                      Comply with COGCC housekeeping rules 12/11/20</p> <p>A follow up on this site inspection needs to be conducted to ensure the compliance issues have been corrected to comply with COGCC rules.                      This is a summary of inspection report.</p>	<p>medinaj</p>	<p>11/11/2021</p>

**Attached Documents**

You can go to COGCC Images (<https://cogcc.state.co.us/weblink/>) and search by document number:

Document Num	Description	URL
699503340	Inspection pictures	<a href="http://ogccweblink.state.co.us/DownloadDocumentPDF.aspx?DocumentId=5579156">http://ogccweblink.state.co.us/DownloadDocumentPDF.aspx?DocumentId=5579156</a>