

**UTAH GAS OP LTD DBA UTAH GAS CORP
FEDERAL-62S101W 22NWNW
Location # 316105**



Battery sign not at tank battery.

**UTAH GAS OP LTD DBA UTAH GAS CORP
FEDERAL-62S101W 22NWNW
Location # 316105**



Label is peeling on tank.

**UTAH GAS OP LTD DBA UTAH GAS CORP
FEDERAL-62S101W 22NWNW
Location # 316105**



The sight glass located on the side of the unit indicates the storage tank is full of an unknown fluid. No form of labeling or markers are present to identify a potential hazard or the contents of the storage tank.



No form of labeling or markers are present to identify a potential hazard or the contents of the storage tank.