

Orifice Meter Test Report

-HESTER GU #2

Date Performed: November 30, 2022 07:33 Rev 1

Sch Month: 11 November

Seq Verified: N/A

User Defined 3: _____

Seq Corrected: N/A

Meter Constants

Calculation Method:	AGA3-1992	FPV Method:	AGA8-Gross2
Pressure Type:	PSIG	Measured HV:	
Atmos. Press.:	11.440	Specific Gravity:	
Pressure Base:	14.73	N2:	
Temp. Base:	60.00	CO2:	

Temp. Base: 60.00 CO2:

DP Calibration

Standard	Found	Left	Flow Rate Error
Reset A.P.0	0.00		
Reset W.P.0	0.00		
0.00	0.00	0.00	
150.00	149.36	150.03	
75.00	74.75	75.03	
13.00	12.98	13.01	
0.00	0.00	0.00	

SP Calibration

Standard (PSIG)	Found (PSIG)	Left (PSIG)	Flow Rate Error
0.00	0.00	0.00	
500.00	499.60	500.00	
38.00	37.92	38.04	

SP Calibration

Standard (PSIG)	Found (PSIG)	Left (PSIG)	Flow Rate Error
0.00	0.00	0.00	
500.00	499.60	500.00	
38.00	37.92	38.04	

Temperature Calibration

Standard 59.50	Found 58.75	Left 58.75	Flow Rate Error

Total Error:	-0.06%
---------------------	--------

Total Error:	-0.06%
---------------------	--------

Witness: _____ Signed: Kevin Chee

% errors stated on this report are based on spot averages and are not the values used for volume corrections