

**FORM
INSP**Rev
X/20**State of Colorado
Oil and Gas Conservation Commission**1120 Lincoln Street, Suite 801, Denver, Colorado 80203
Phone: (303) 894-2100 Fax: (303) 894-2109

Inspection Date:

04/25/2023

Submitted Date:

04/25/2023

Document Number:

702401892

FIELD INSPECTION FORMLoc ID 318238 Inspector Name: Revas, Robbie On-Site Inspection ☐ 2A Doc Num: _____**Operator Information:**

OGCC Operator Number: 46290

Name of Operator: KP KAUFFMAN COMPANY INC

Address: 1700 LINCOLN ST STE 4550

City: DENVER State: CO Zip: 80203

Status Summary:

- ☐ THIS IS A FOLLOW UP INSPECTION
- ☒ FOLLOW UP INSPECTION REQUIRED
- ☐ NO FOLLOW UP INSPECTION REQUIRED

Findings:

9 Number of Comments

1 Number of Corrective Actions

☒ Corrective Action Response Requested**ANY CORRECTIVE ACTION(S) FROM
PREVIOUS INSPECTIONS THAT HAVE NOT
BEEN ADDRESSED ARE STILL APPLICABLE****Contact Information:**

Contact Name	Phone	Email	Comment
Anderson, Laurel		laurel.anderson@state.co.us	
,		cogcc@kpk.com	All Inspections
,		rwatzman@kpk.com	All Inspections

Inspected Facilities:

Facility ID	Type	Status	Status Date	Well Class	API Num	Facility Name	Insp Status
240940	WELL	SI	08/01/2022	OW	123-08728	1415 CORP. UNIT E 1	SI
446468	TANK BATTERY	AC	09/17/2014		-	1415 CORP UNIT E-F	SI

General Comment:

LocationOverall Good: ☒**Signs/Marker:**

Type	TANK LABELS/PLACARDS		
Comment:	adequate		
Corrective Action:		Date:	
Type	BATTERY		
Comment:	adequate		
Corrective Action:		Date:	

Emergency Contact Number:

Comment:		
Corrective Action:		Date: _____

Overall Good: ☒**Spills:**

Type	Area	Volume		
------	------	--------	--	--

In Containment: No

Comment: _____

☐ Multiple Spills and Releases?**Fencing/:**

Type			
Comment:			
Corrective Action:		Date:	

Equipment:

Type: Other	# 1		corrective date
Comment:	flow line manifold		
Corrective Action:		Date:	
Type: Horizontal Heater Treater	# 1		
Comment:			
Corrective Action:		Date:	

Tanks and Berms:

Contents	#	Capacity	Type	Tank ID	SE GPS
PRODUCED WATER	1	<100 BBLS	PBV CONCRETE		,
Comment:					
Corrective Action:					Date:

Paint

Condition	
Other (Content)	
Other (Capacity) 50bbl	
Other (Type)	

Berms						
Type	Capacity	Permeability (Wall)	Permeability (Base)	Maintenance		
Earth	Adequate	Walls Sufficient	Base Sufficient	Adequate		
Comment:				Shares containment with crude tanks.		
Corrective Action:				Date:		
Contents	#	Capacity	Type	Tank ID	SE GPS	
CRUDE OIL	2	300 BBLs	STEEL AST		40.110510,-104.835860	
Comment:				the north crude oil tank is rusted and oitting along the bottom seam and has several slow drips onto the concrete pad it sits on.		
Corrective Action:				Date:		05/25/2023

Paint

Condition	Adequate	
Other (Content)		
Other (Capacity)		
Other (Type)		

Berms

Type	Capacity	Permeability (Wall)	Permeability (Base)	Maintenance		
Earth	Adequate	Walls Sufficient	Base Sufficient	Adequate		
Comment:						
Corrective Action:				Date:		

Wells Served By Facilities AboveAirsID

API Number	API Number	AirsID
123-08728		
123-09014		

Venting:

Yes/No			
Comment:			
Corrective Action:	Date:		

Flaring:

Type			
Comment:			
Corrective Action:	Date:		

Inspected FacilitiesFacility ID: 240940 Type: WELL API Number: 123-08728 Status: SI Insp. Status: SI**Idle Well**Purpose: ☒ Shut In ☐ Temporarily Abandoned Reminder: _____Comment: SI

Corrective Action: _____ Date: _____

BradenHeadDate of Last Brhd Test: 02/20/2023 Annual Brhd Completed? YesLast Brhd Test Results Initial Surf Csg Pressure: 0 Fluid Type: _____End Surf Csg Pressure: 0

Comment: _____

Corrective Action: _____ Date: _____

Facility ID: 446468 Type: TANK API Number: - Status: AC Insp. Status: SI

Reclamation - Storm Water - Pit**Storm Water:**

Loc Erosion BMPs	BMP Maintenance	Lease Road Erosion BMPs	Lease BMP Maintenance	Chemical BMPs	Chemical BMP Maintenance	Comment
Gravel	Pass	Gravel	Pass			

Comment: Corrective Action: Date: **Pits:** ☒ NO SURFACE INDICATION OF PIT**COGCC Comments**

Comment	User	Date
<p>COGCC Inspection Report Summary</p> <p>On Tuesday 4-25-2023 at approximately 1415 hrs. I, Inspector Robbie Revas, Conducted an on-site inspection:</p> <p>Operator: KP Kauffman</p> <p>Location name: 1415 Corp Unit E1 & F1 Tank Battery</p> <p>Facility # 446468</p> <p>County: Weld</p> <p>Weather: Cloudy, windy and cold.</p> <p>Location: Dry.</p> <p>While there, I observed tank battery, SI at the time of inspection.</p> <p>During this inspection, I observed the following possible compliance issues:</p> <p>609.b Crude & Condensate Tanks: North Crude tank is rusted/pitted and slowly dripping on cement pad, CA date 5-25-2023.</p> <p>See attached photos.</p> <p>At 1440 hrs. I spoke with KP Kauffman Supervisor Mani Silva about the crude oil tank issue and he said he will send someone out to take a look.</p> <p>A follow up site inspection is needed to ensure that the addressed Compliance issues comply with COGCC rules</p>	revasr	04/25/2023

Attached DocumentsYou can go to COGCC Images (<https://cogcc.state.co.us/weblink/>) and search by document number:

Document Num	Description	URL
403384272	INSPECTION SUBMITTED	http://ogccweblink.state.co.us/DownloadDocumentPDF.aspx?DocumentId=6093455
702401893	location pics	http://ogccweblink.state.co.us/DownloadDocumentPDF.aspx?DocumentId=6093449