

**Operator: 8 North**

**Location Name: LOYD PC GD 33-13 TANK**

**Loc ID: 419917**

**Inspection: 696305318**



**Exhibit A**

**CA:** 500 BBL Tank - NFPA Label; see photos. Install sign to comply with Rule 605.h.

**CA Resolution:** Operator has installed new NFPA labels on the 500 bbl Tank to comply with Rule 605.h.