

**PRODUCED WATER STORAGE TANK EMISSIONS**

Operator: Chaco Energy Company  
 Facility Name: Some State  
 Emission Point Description: (1) 300 bbl and (1) 500 bbl liquid manifolded storage tank

Actual Throughput (gal)	Throughput (bbl)	PTE Throughput (bbl)
3,066,000	73,000	73,000

Actual W&B Emissions (lb/yr)	5% of Actual W&B Emissions (lb/yr)
315.1635	15.758175

EMISSION FACTORS & EMISSIONS SUMMARY							
Criteria Pollutant	Emission Factors			Actual Emissions		Potential to Emit	
	Uncontrolled	Units	Estimation Method	Uncontrolled (tons/year)	Controlled (tons/year)	Uncontrolled (tons/year)	Controlled (tons/year)
VOC	0.0035	lb/bbl	PS Memo 17-01, AP-42	0.13	0.13	0.13	0.13
Greenhouse Gas	Uncontrolled	Units	Estimation Method	Uncontrolled (tons/year)	Controlled (tons/year)	Uncontrolled (tons/year)	Controlled (tons/year)
CO <sub>2</sub>	0.0217	lb/bbl	PS Memo 17-01, AP-42	0.79	0.79	0.79	0.79
Methane	0.0091	lb/bbl	PS Memo 17-01, AP-42	0.33	0.33	0.33	0.33
Ethane	0.0006	lb/bbl	PS Memo 17-01, AP-42	0.02	0.02	0.02	0.02
Hazardous Air Pollutant	Uncontrolled	Units	Estimation Method	Uncontrolled (lb/year)	Controlled (lb/year)	Uncontrolled (lb/year)	Controlled (lb/year)
Benzene	0.0006	lb/bbl	PS Memo 17-01, AP-42	4	4	4	4
Toluene	0.0021	lb/bbl	PS Memo 17-01, AP-42	15	15	15	15
Ethylbenzene	0.0006	lb/bbl	PS Memo 17-01, AP-42	4	4	4	4
Xylene	0.0023	lb/bbl	PS Memo 17-01, AP-42	17	17	17	17
n-Hexane	0.0012	lb/bbl	PS Memo 17-01, AP-42	9	9	9	9
2,2,4 Trimethylpentane	0.0000	lb/bbl	PS Memo 17-01, AP-42	0	0	0	0

Storage Vessel 1		
Capacity (bbl)	Annual Throughput (gal/yr)	W&B Emissions (lb/yr)
300	1,149,750	136.0792

Storage Vessel 2		
Capacity (bbl)	Annual Throughput (gal/yr)	W&B Emissions (lb/yr)
500	1,916,250	179.0843

ACTUAL ANNUAL EMISSION TOTALS							
Pollutant	Mass Fraction	Working & Breathing		Flash		Working & Breathing + Flash	
		Uncontrolled (lb/year)	Controlled (lb/year)	Uncontrolled (lb/year)	Controlled (lb/year)	Uncontrolled (lb/year)	Controlled (lb/year)
VOC	0.0853	1.34	1.34	250.90	250.90	252.25	252.25
CO <sub>2</sub>	0.5350	8.43	8.43	1574.18	1574.18	1582.61	1582.61
Methane	0.2246	3.54	3.54	661.06	661.06	664.60	664.60
Ethane	0.0158	0.25	0.25	46.63	46.63	46.88	46.88
Benzene	0.0015	0.02	0.02	4.27	4.27	4.30	4.30
Toluene	0.0052	0.08	0.08	15.32	15.32	15.40	15.40
Ethylbenzene	0.0015	0.02	0.02	4.38	4.38	4.40	4.40
Xylene	0.0058	0.09	0.09	16.93	16.93	17.02	17.02
n-Hexane	0.0030	0.05	0.05	8.79	8.79	8.84	8.84
2,2,4 Trimethylpentane	0.0000	0.00	0.00	0.00	0.00	0.00	0.00

Working & Breathing emissions calculated using AP-42 Section 7.1 (June 2020).

FLASH LIBERATION ANALYSIS						
Actual or Representative Sample	Sample Collection Point	Sample Date	Gas to Water Ratio (scf/bbl)	Sample Molecular Weight (lb/lb-mole)	Flash Gas Volume (scf/yr)	Gas Molar Volume (scf/lb-mole)
Actual	Heater Treater	5/4/2021	0.5	30.5553	36,500	379

Flash Gas Extended Analysis				
Constituent	Weight %	Mass Fraction	Uncontrolled Emissions (lb/year)	Emission Factor (lb/bbl)
Hydrogen Sulfide	0.0000	0.0000	0.0000	0.0000
Carbon Dioxide	53.4952	0.5350	1574.1836	0.0216
Nitrogen	13.9291	0.1393	409.8851	0.0056
Methane	22.4648	0.2246	661.0625	0.0091
Ethane	1.5845	0.0158	46.6262	0.0006
Propane	0.4807	0.0048	14.1466	0.0002
Isobutane	2.1038	0.0210	61.9075	0.0008
n-Butane	0.2372	0.0024	6.9809	0.0001
Isopentane	0.2760	0.0028	8.1211	0.0001
n-Pentane	0.0920	0.0009	2.7076	0.0000
Cyclopentane	0.0243	0.0002	0.7161	0.0000
n-Hexane	0.2988	0.0030	8.7916	0.0001
Cyclohexane	0.1158	0.0012	3.4067	0.0000
Other Hexanes	0.6256	0.0053	16.4108	0.0003
Heptanes	0.4340	0.0043	12.7897	0.0002
Methylcyclohexane	0.1834	0.0018	5.3968	0.0001
2,2,4 Trimethylpentane	0.0000	0.0000	0.0000	0.0000
Benzene	0.1452	0.0015	4.2724	0.0001
Toluene	0.5207	0.0052	15.3229	0.0002
Ethylbenzene	0.1488	0.0015	4.3794	0.0001
Xylenes	0.5753	0.0058	16.9304	0.0002
Octanes	0.6094	0.0061	17.9318	0.0002
Nonanes	0.3203	0.0032	9.4249	0.0001
Decanes Plus	1.3351	0.0134	39.2865	0.0005

Emission factors calculated using guidance from APCD PS-Memo 17-01, Section 5.2 (May 31, 2017).





5530 Marshall Street  
 Arvada, Colorado 80002  
 Phone: 303-420-5949  
 Fax: 303-420-5920

**FLASH LIBERATION ANALYSIS OF SEPARATOR WATER**

**SAMPLE DATA**

PROJECT NO..... OG-2021-0245  
 COMPANY NAME..... CGRS  
 SITE..... Some State  
 UNIT ID..... Heater Treater  
 SAMPLED BY..... AJM

SAMPLE ID..... Pressurized Water  
 ANALYSIS DATE..... 5/6/2021  
 SAMPLE DATE..... 5/4/2021  
 CYLINDER NO..... 37525  
 LAB ANALYST..... CLB

**FIELD DATA**

SAMPLE PRESSURE..... 16.1 psig  
 AMBIENT PRESSURE..... 12.7 psi

SAMPLE TEMP..... 127 F  
 AMBIENT TEMP..... 60 F

COMMENTS: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**Flash Liberation of Pressurized Water**

	Pressure	Temperature
Separator Produced Water	16 psig	127 °F
Stock Tank	12.7 psia	60 °F
Base Conditions	14.65 psi	60 °F

**Flash Liberation Results**

	Result	Units
Gas Water Ratio	<0.5	SCF flashed gas/bbl stock tank liquid
Gas Specific Gravity	1.0550	Air = 1.00

**Quality Assurance**

	Result
Duplicate GWR RSD (20% max.)	0.00%



5530 Marshall Street  
 Arvada, Colorado 80002  
 Phone: 303-420-5949  
 Fax: 303-420-5920

**Flashed Gas Extended Analysis**

**SAMPLE DATA**

PROJECT NO.....	OG-2021-0245	SAMPLE ID.....	Flashed Gas
COMPANY NAME.....	CGRS	ANALYSIS DATE.....	5/6/2021
SITE.....	Some State	SAMPLE DATE.....	5/4/2021
UNIT ID.....	Heater Treater	CYLINDER NO.....	37525
SAMPLED BY.....	AJM	LAB ANALYST.....	CLB

**LAB CONDITIONS**

PRESSURE.....	12.2 psi	TEMPERATURE.....	72 F
---------------	----------	------------------	------

COMMENTS: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**LABORATORY DATA**

COMPONENT	MOLE %	WT%	GPM
HYDROGEN SULFIDE.....	0.0000	0.0000	0.0000
CARBON DIOXIDE.....	37.1412	53.4952	6.3432
NITROGEN.....	15.1930	13.9291	1.6727
METHANE.....	42.7876	22.4648	7.2592
ETHANE.....	1.6101	1.5845	0.4309
PROPANE.....	0.3331	0.4807	0.0918
ISOBUTANE.....	1.1060	2.1038	0.3622
N-BUTANE.....	0.1247	0.2372	0.0393
ISOPENTANE.....	0.1169	0.2760	0.0428
N-PENTANE.....	0.0390	0.0920	0.0141
CYCLOPENTANE.....	0.0106	0.0243	0.0031
N-HEXANE.....	0.1059	0.2988	0.0436
CYCLOHEXANE.....	0.0420	0.1158	0.0143
OTHER HEXANES.....	0.2234	0.6256	0.0879
HEPTANES.....	0.1337	0.4340	0.0584
METHYLCYCLOHEXANE.....	0.0571	0.1834	0.0229
2,2,4 TRIMETHYLPENTANE.....	0.0000	0.0000	0.0000
BENZENE.....	0.0568	0.1452	0.0159
TOLUENE.....	0.1727	0.5207	0.0578
ETHYLBENZENE.....	0.0428	0.1488	0.0165
XYLENES.....	0.1656	0.5753	0.0642
OCTANES.....	0.1692	0.6094	0.0721
NONANES.....	0.0799	0.3203	0.0375
DECANES PLUS.....	0.2887	1.3351	0.1728
SUBTOTAL	100.0000	100.0000	16.9235
OXYGEN/ARGON	0.0000	0.0000	0.0000
<b>TOTAL</b>	<b>100</b>	<b>100</b>	<b>16.9235</b>

**BTU @**

MOLECULAR WEIGHT.....	30.5553	NET DRY REAL	545.2928 /scf
RELATIVE DENSITY (AIR=1).....	1.0550	GROSS DRY REAL	602.2606 /scf
COMPRESSIBILITY FACTOR.....	0.9967	GROSS WET REAL	591.6867 /scf

**OKLAHOMA DEPARTMENT OF ENVIRONMENTAL QUALITY**  
**AQD Storage Tank Calculation Tool (21294)**  
**Calculation Report**  
**Based on AP-42 (06/2020) Section 7.1: Organic Liquid Storage Tanks**

Print this page

**INPUT SUMMARY**

**Identification**

Tank type Vertical Fixed Roof  
 Tank identifier 300 bbl water tank

**Meteorological Data:**

Nearest major city: Denver, CO

**Tank Contents:**

Data source Manual Entry  
 Liquid category Crude Oil  
 Liquid name  
 Vapor molecular weight, lb/lb-mole  $M_V$  30.5553  
 Reid vapor pressure, psia RVP 1.1000

**Tank Dimensions:**

Tank shell height, ft  $H_S$  15.0000  
 Tank diameter, ft D 12.0000  
 Maximum liquid height, ft  $H_{LX}$  14.0000  
 Minimum liquid height, ft  $H_{LN}$  1.0000  
 Liquid height, ft  $H_L$  7.5000  
 Number of turnovers per year, dimensionless N 104.5276  
 Annual net throughput, gal/yr 1,149,750.0000  
 Annual net throughput, bbl/yr Q 27,375.0000  
 Flashing/vapor balanced unloading? No

**Paint Characteristics:**

Shell color/shade Aluminum: Diffuse  
 Shell condition Average  
 Roof color/shade Aluminum: Diffuse  
 Roof condition Average

**Roof Characteristics:**

Roof type Dome Roof  
 Tank roof height, ft  $H_R$  0.0000  
 Tank dome roof radius, ft  $R_R$  12

**Breather Vent Settings:**

Breather vent vacuum setting, psig	$P_{BV}$	-0.0300
Breather vent pressure setting, psig	$P_{BP}$	0.0300

**Insulation Characteristics:**

Tank insulation	None
Tank heating	No

<b>METEOROLOGICAL DATA</b>
----------------------------

Nearest major city:	Denver, CO
Average daily ambient temperature, °R	$T_{AA}$ 510.4000
Average daily minimum ambient temperature, °R	$T_{AN}$ 497.6000
Average daily maximum ambient temperature, °R	$T_{AX}$ 523.2000
Average daily ambient temperature range, °R	$\Delta T_A$ 25.6000
Average wind speed, mph	$v$ 9.4000
Average daily total insolation factor, Btu/ft <sup>2</sup> •d	$I$ 1,491.0000
Atmospheric pressure, psi	$P_A$ 12.0800

<b>LIQUID DATA</b>
--------------------

Liquid category	Crude Oil
Liquid name	
Liquid bulk temperature, °R	$T_B$ 513.2627
Average daily liquid surface temperature, °R	$T_{LA}$ 515.8997
Average daily minimum liquid surface temperature, °R	$T_{LN}$ 506.7787
Average daily maximum liquid surface temperature, °R	$T_{LX}$ 525.0207
Vapor pressure at average daily liquid surface temperature, psia	$P_{VA}$ 0.3256
Vapor pressure at the average daily minimum liquid surface temperature, psia	$P_{VN}$ 0.2538
Vapor pressure at the average daily maximum liquid surface temperature, psia	$P_{VX}$ 0.4142
Vapor molecular weight, lb/lb-mole	$M_V$ 30.5553
Reid vapor pressure, psia	RVP 1.1000
Constant in vapor pressure equation, dimensionless	$A$ 12.7278
Constant in vapor pressure equation, °R	$B$ 7,145.1028

<b>CALCULATION DETAILS</b>
----------------------------

**Standing Losses**

Standing losses, lb/yr	$L_S$	42.5754
------------------------	-------	---------

Vapor space volume, ft <sup>3</sup>	V <sub>V</sub>	941.1960
Vapor density, lb/ft <sup>3</sup>	W <sub>V</sub>	0.0018
Vapor space expansion factor, per day	K <sub>E</sub>	0.0793
Vented vapor saturation factor, dimensionless	K <sub>S</sub>	0.8744

**Vapor Space Volume**

Vapor space volume, ft <sup>3</sup>	V <sub>V</sub>	941.1960
Tank diameter, ft	D	12.0000
Vapor space outage, ft	H <sub>VO</sub>	8.3220

**Vapor Space Outage**

Vapor space outage, ft	H <sub>VO</sub>	8.3220
Tank shell height, ft	H <sub>S</sub>	15.0000
Liquid height, ft	H <sub>L</sub>	7.5000
Roof outage, ft	H <sub>RO</sub>	0.8220

**Roof Outage**

Roof outage, ft	H <sub>RO</sub>	0.8220
Tank roof height, ft	H <sub>R</sub>	1.6080
Tank shell radius, ft	R <sub>S</sub>	6.0000
Tank dome roof radius, ft	R <sub>R</sub>	12.0000

**Vapor Density**

Vapor density, lb/ft <sup>3</sup>	W <sub>V</sub>	0.0018
Vapor molecular weight, lb/lb-mole	M <sub>V</sub>	30.5553
Vapor pressure at average daily liquid surface temperature, psia	P <sub>VA</sub>	0.3256
Ideal gas constant, psia•ft <sup>3</sup> /lb-mole•°R	R	10.7310
Average vapor temperature, °R	T <sub>V</sub>	518.5367
Tank roof surface solar absorptance, dimensionless	α <sub>R</sub>	0.6400
Tank shell surface solar absorptance, dimensionless	α <sub>S</sub>	0.6400
Average daily total insolation factor, Btu/ft <sup>2</sup> •d	I	1,491.0000

**Vapor Space Expansion Factor**

Vapor space expansion factor, per day	K <sub>E</sub>	0.0793
Average daily vapor temperature range, °R	ΔT <sub>V</sub>	36.4841
Average daily vapor pressure range, psi	ΔP <sub>V</sub>	0.1604
Breather vent pressure setting range, psig	ΔP <sub>B</sub>	0.0600
Atmospheric pressure, psi	P <sub>A</sub>	12.0800
Vapor pressure at average daily liquid surface temperature, psia	P <sub>VA</sub>	0.3256
Average daily liquid surface temperature, °R	T <sub>LA</sub>	515.8997

**Vented Vapor Saturation Factor**

Vented vapor saturation factor, dimensionless	$K_S$	0.8744
Vapor pressure at average daily liquid surface temperature, psia	$P_{VA}$	0.3256
Vapor space outage, ft	$H_{VO}$	8.3220

**Working Losses**

Working losses, lb/yr	$L_W$	93.5039
Net working loss throughput, ft <sup>3</sup> /yr	$V_Q$	153,683.2500
Turnover factor, dimensionless	$K_N$	0.4537
Working loss product factor for fixed roof tanks, dimensionless	$K_P$	0.7500
Vapor density, lb/ft <sup>3</sup>	$W_V$	0.0018
Vent setting correction factor, dimensionless	$K_B$	1.0000

---

<b>EMISSIONS SUMMARY</b>
--------------------------

**Total Losses**

Standing losses, lb/yr	$L_S$	42.5754
Working losses, lb/yr	$L_W$	93.5039
Total routine losses, lb/yr	$L_T$	136.0792

**OKLAHOMA DEPARTMENT OF ENVIRONMENTAL QUALITY**  
**AQD Storage Tank Calculation Tool (21294)**  
**Calculation Report**  
**Based on AP-42 (06/2020) Section 7.1: Organic Liquid Storage Tanks**

Print this page

**INPUT SUMMARY**

**Identification**

Tank type Vertical Fixed Roof  
 Tank identifier 500 bbl water tank

**Meteorological Data:**

Nearest major city: Denver, CO

**Tank Contents:**

Data source Manual Entry  
 Liquid category Crude Oil  
 Liquid name  
 Vapor molecular weight, lb/lb-mole  $M_V$  30.5553  
 Reid vapor pressure, psia RVP 1.1000

**Tank Dimensions:**

Tank shell height, ft  $H_S$  20.0000  
 Tank diameter, ft D 12.0000  
 Maximum liquid height, ft  $H_{LX}$  14.0000  
 Minimum liquid height, ft  $H_{LN}$  1.0000  
 Liquid height, ft  $H_L$  7.5000  
 Number of turnovers per year, dimensionless N 174.2126  
 Annual net throughput, gal/yr 1,916,250.0000  
 Annual net throughput, bbl/yr Q 45,625.0000  
 Flashing/vapor balanced unloading? No

**Paint Characteristics:**

Shell color/shade Aluminum: Diffuse  
 Shell condition Average  
 Roof color/shade Aluminum: Diffuse  
 Roof condition Average

**Roof Characteristics:**

Roof type Dome Roof  
 Tank roof height, ft  $H_R$  0.0000  
 Tank dome roof radius, ft  $R_R$  12

**Breather Vent Settings:**

Breather vent vacuum setting, psig	$P_{BV}$	-0.0300
Breather vent pressure setting, psig	$P_{BP}$	0.0300

**Insulation Characteristics:**

Tank insulation	None
Tank heating	No

<b>METEOROLOGICAL DATA</b>
----------------------------

Nearest major city:	Denver, CO
Average daily ambient temperature, °R	$T_{AA}$ 510.4000
Average daily minimum ambient temperature, °R	$T_{AN}$ 497.6000
Average daily maximum ambient temperature, °R	$T_{AX}$ 523.2000
Average daily ambient temperature range, °R	$\Delta T_A$ 25.6000
Average wind speed, mph	$v$ 9.4000
Average daily total insolation factor, Btu/ft <sup>2</sup> •d	$I$ 1,491.0000
Atmospheric pressure, psi	$P_A$ 12.0800

<b>LIQUID DATA</b>
--------------------

Liquid category	Crude Oil
Liquid name	
Liquid bulk temperature, °R	$T_B$ 513.2627
Average daily liquid surface temperature, °R	$T_{LA}$ 515.6940
Average daily minimum liquid surface temperature, °R	$T_{LN}$ 506.5568
Average daily maximum liquid surface temperature, °R	$T_{LX}$ 524.8312
Vapor pressure at average daily liquid surface temperature, psia	$P_{VA}$ 0.3238
Vapor pressure at the average daily minimum liquid surface temperature, psia	$P_{VN}$ 0.2522
Vapor pressure at the average daily maximum liquid surface temperature, psia	$P_{VX}$ 0.4122
Vapor molecular weight, lb/lb-mole	$M_V$ 30.5553
Reid vapor pressure, psia	RVP 1.1000
Constant in vapor pressure equation, dimensionless	$A$ 12.7278
Constant in vapor pressure equation, °R	$B$ 7,145.1028

<b>CALCULATION DETAILS</b>
----------------------------

**Standing Losses**

Standing losses, lb/yr	$L_S$	63.2292
------------------------	-------	---------

Vapor space volume, ft <sup>3</sup>	V <sub>V</sub>	1,506.6827
Vapor density, lb/ft <sup>3</sup>	W <sub>V</sub>	0.0018
Vapor space expansion factor, per day	K <sub>E</sub>	0.0794
Vented vapor saturation factor, dimensionless	K <sub>S</sub>	0.8139

**Vapor Space Volume**

Vapor space volume, ft <sup>3</sup>	V <sub>V</sub>	1,506.6827
Tank diameter, ft	D	12.0000
Vapor space outage, ft	H <sub>VO</sub>	13.3220

**Vapor Space Outage**

Vapor space outage, ft	H <sub>VO</sub>	13.3220
Tank shell height, ft	H <sub>S</sub>	20.0000
Liquid height, ft	H <sub>L</sub>	7.5000
Roof outage, ft	H <sub>RO</sub>	0.8220

**Roof Outage**

Roof outage, ft	H <sub>RO</sub>	0.8220
Tank roof height, ft	H <sub>R</sub>	1.6080
Tank shell radius, ft	R <sub>S</sub>	6.0000
Tank dome roof radius, ft	R <sub>R</sub>	12.0000

**Vapor Density**

Vapor density, lb/ft <sup>3</sup>	W <sub>V</sub>	0.0018
Vapor molecular weight, lb/lb-mole	M <sub>V</sub>	30.5553
Vapor pressure at average daily liquid surface temperature, psia	P <sub>VA</sub>	0.3238
Ideal gas constant, psia•ft <sup>3</sup> /lb-mole•°R	R	10.7310
Average vapor temperature, °R	T <sub>V</sub>	518.1253
Tank roof surface solar absorptance, dimensionless	α <sub>R</sub>	0.6400
Tank shell surface solar absorptance, dimensionless	α <sub>S</sub>	0.6400
Average daily total insolation factor, Btu/ft <sup>2</sup> •d	I	1,491.0000

**Vapor Space Expansion Factor**

Vapor space expansion factor, per day	K <sub>E</sub>	0.0794
Average daily vapor temperature range, °R	ΔT <sub>V</sub>	36.5488
Average daily vapor pressure range, psi	ΔP <sub>V</sub>	0.1600
Breather vent pressure setting range, psig	ΔP <sub>B</sub>	0.0600
Atmospheric pressure, psi	P <sub>A</sub>	12.0800
Vapor pressure at average daily liquid surface temperature, psia	P <sub>VA</sub>	0.3238
Average daily liquid surface temperature, °R	T <sub>LA</sub>	515.6940

**Vented Vapor Saturation Factor**

Vented vapor saturation factor, dimensionless	$K_S$	0.8139
Vapor pressure at average daily liquid surface temperature, psia	$P_{VA}$	0.3238
Vapor space outage, ft	$H_{VO}$	13.3220

**Working Losses**

Working losses, lb/yr	$L_W$	115.8551
Net working loss throughput, ft <sup>3</sup> /yr	$V_Q$	256,138.7500
Turnover factor, dimensionless	$K_N$	0.3389
Working loss product factor for fixed roof tanks, dimensionless	$K_P$	0.7500
Vapor density, lb/ft <sup>3</sup>	$W_V$	0.0018
Vent setting correction factor, dimensionless	$K_B$	1.0000

---

<b>EMISSIONS SUMMARY</b>
--------------------------

**Total Losses**

Standing losses, lb/yr	$L_S$	63.2292
Working losses, lb/yr	$L_W$	115.8551
Total routine losses, lb/yr	$L_T$	179.0843