

State of Colorado  
Energy & Carbon Management Commission

1120 Lincoln Street, Suite 801, Denver, Colorado 80203  
Phone: (303) 894-2100 Fax: (303) 894-2109



Document Number:

402291179

Date Received:

01/21/2020

## FIR RESOLUTION FORM

Overall Status: CAC

CA Summary:

4 of 4 CAs from the FIR responded to on this Form

4 CA Completed  
0 Factual Review Request

### OPERATOR INFORMATION

OGCC Operator Number: 10330

Name of Operator: INVESTMENT EQUIPMENT LLC

Address: 558 CASTLE PINES PKWY UNIT B-4

City: CASTLE PINES State: CO Zip: 80108

Contact Name and Telephone:

Name: \_\_\_\_\_

Phone: ( ) \_\_\_\_\_ Fax: ( ) \_\_\_\_\_

Email: \_\_\_\_\_

Additional Operator Contact:

Contact Name

Chisholm, Jim

Phone

405-642-9437

Email

investmentequipment@gmail.com

### COGCC INSPECTION SUMMARY:

FIR Document Number: 687400719

Inspection Date: 01/03/2020

FIR Submit Date: 01/03/2020

FIR Status: \_\_\_\_\_

### Inspected Operator Information:

Company Name: INVESTMENT EQUIPMENT LLC

Company Number: 10330

Address: 412 W PLATTE AVE

City: FT MORGAN State: CO Zip: 80701

### LOCATION - Location ID: 319632

Location Name: Badger Creek Number: 22-N Facility County: \_\_\_\_\_

Qtrqr: SWSE Sec: 22 Twp: 2S Range: 57W Meridian: 6

Latitude: 39.859970 Longitude: -103.747455

### FACILITY - API Number: 05-001- -00 Facility ID: 319632

Facility Name: Badger Creek Number: 22-N Facility

Qtrqr: SWSE Sec: 22 Twp: 2S Range: 57W Meridian: 6

Latitude: 39.859970 Longitude: -103.747455

### CORRECTIVE ACTIONS:

1 ☒ CA# 135700

Corrective Action: Paint tanks per Rule 804.

Date: 07/03/2020

Response: CA COMPLETED

Date of Completion: 01/20/2020

Operator Comment: Will evaluate painting water tank after winter weather.

COGCC Decision: Approved via an AMI

COGCC  
Representative:

2 ☒ CA# 135701

Corrective Action: Paint tanks per Rule 804.

Date: 07/03/2020

Response: CA COMPLETED

Date of Completion: 01/20/2020

Operator  
Comment: Will evaluate painting crude oil tanks after winter weather.

COGCC Decision: Approved via an AMI

COGCC  
Representative:

3 ☒ CA# 135702

Corrective Action: Install sign to comply with Rule 210.d.

Date: 03/03/2020

Response: CA COMPLETED

Date of Completion: 01/20/2020

Operator  
Comment: Installed correct tank labels on water tank.

COGCC Decision: Approved via an AMI

COGCC  
Representative:

4 ☒ CA# 135703

Corrective Action: Install sign to comply with Rule 210.d.

Date: 03/03/2020

Response: CA COMPLETED

Date of Completion: 01/20/2020

Operator  
Comment: installed hazard label and 1000 gal size on propane tank.

COGCC Decision: Approved via an AMI

COGCC  
Representative:

#### OPERATOR COMMENT AND SUBMITTAL

Comment:

I hereby certify that the statements made in this form are, to the best of my knowledge, true, correct, and complete.

Print Name: Jim Chisholm

Signed:

Title: Manager / Member

Date: 1/21/2020 3:07:00 PM

### ATTACHMENT LIST

View Attachments in Imaged Documents on COGCC website (<http://ogccweblink.state.co.us/>) - Search by Document Number.

<u>Document Number</u>	<u>Description</u>
402291179	FIR RESOLUTION SUBMITTED
402291246	Pictures of water tank
402291248	Picture of propane tank

Total Attach: 3 Files