

Calibration Report: FB103 - A1G2 - Fonte 31-27**Meter ID: 7015779****Meter Description: Fonte 31-27/15842268****Operator: LOI**

Differential Pressure Calibration (AIN A1, EU)

Tag: Diff Pres Range: 0.0 - 250.0 End-Element Diameter: 0.25 Pipe Diameter: 2.067

8/8/2023 12:24:43	Verify Calibration	Actual:	-0.312	Expected:	0.000	Deviation:	-0.312	-0.1248 %
8/8/2023 12:25:02	Set Low Reading	As Found:	-0.312	As Left:	0.000	Deviation:	-0.312	-0.1248 %
8/8/2023 12:26:12	Set High Reading	As Found:	250.017	As Left:	250.000	Deviation:	0.017	0.0068 %
8/8/2023 12:26:48	Set Mid Point 1	As Found:	15.000	As Left:	15.000	Deviation:	0.000	0.0000 %
8/8/2023 12:27:35	Verify Calibration	Actual:	0.017	Expected:	0.000	Deviation:	0.017	0.0068 %
8/8/2023 12:28:18	Verify Calibration	Actual:	249.958	Expected:	250.000	Deviation:	-0.042	-0.0168 %
8/8/2023 12:29:11	Verify Calibration	Actual:	15.051	Expected:	15.000	Deviation:	0.051	0.0204 %

Static Pressure Calibration (AIN A2, EU)

Tag: Static Range: 0.0 - 400.0 Pressure: Gauge Tap Location: Upstream

8/8/2023 12:31:38	Verify Calibration	Actual:	-0.027	Expected:	0.000	Deviation:	-0.027	-0.0068 %
8/8/2023 12:32:19	Verify Calibration	Actual:	250.054	Expected:	250.000	Deviation:	0.054	0.0135 %
8/8/2023 12:32:50	Verify Calibration	Actual:	30.000	Expected:	30.000	Deviation:	0.000	0.0000 %

Temperature Calibration (AIN A3, EU)

Tag: RTD Range: -40.0 - 160.0

8/8/2023 12:36:06	Verify Calibration	Actual:	85.581	Expected:	85.100	Deviation:	0.481	0.2405 %
-------------------	--------------------	---------	--------	-----------	--------	------------	-------	----------