

McConnell 01-12  
Brent Jones  
Orifice: .375 (Universal)

SENSOR CALIBRATION REPORT

Saved to: C:\Users\Owner\Desktop\BLANK4\MCCON112.cal  
Created on: 2024/03/12 08:54:51

Meter Tag: MCCON112  
Sensor Type: DP

AS LEFT:	Reference	Measured	Units
	-----	-----	-----
	0.0	0.04	InH2O
	125.0	125.11	InH2O
	250.0	250.09	InH2O

SENSOR CALIBRATION REPORT

Saved to: C:\Users\Owner\Desktop\BLANK4\MCCON112.cal  
Created on: 2024/03/12 08:59:12

Meter Tag: MCCON112  
Sensor Type: SP

AS LEFT:	Reference	Measured	Units
	-----	-----	-----
	13	13.1	psi
	138	138.1	psi
	263	263.1	psi

SENSOR CALIBRATION REPORT

Saved to: C:\Users\Owner\Desktop\BLANK4\MCCON112.cal  
Created on: 2024/03/12 08:59:12

Meter Tag: MCCON112  
Sensor Type: PT

AS LEFT:	Reference	Measured	Units
	-----	-----	-----
	52.5	52.59	DegF