



**OFFICE OF THE STATE ENGINEER
DIVISION OF WATER RESOURCES**

1313 Sherman Street-Room 818
Denver, Colorado 80203
(303) 866-3581

SCANNED

**TO: Lamar Feedyard, Inc.
RE: Application Receipt Nos. 93294**

November 7, 1988
FROM: Keith Vander Horst

Keith Vander Horst

Your application for a permit to construct a well is being returned for the reasons indicated below. The corrections and/or additional information we are requesting is required for evaluation of the application. Please initial any changes or overstrikes you make on the form.

Dear Mr. Randle:

In our telephone conversation of October 27, 1988 I indicated that I needed a statement from you in which you acknowledged that you realized that this proposed well would be in close proximity to your existing well 25557-F, that due to this close proximity each well's pumping could adversely affect the other, and that you wished to locate the new well at this site regardless. We need this statement prior to issuing the well permit.

The reason we need this statement is that Colorado Statute does not allow us to issue a new well permit such as yours if it will be within 600 feet of an existing well, unless a hearing is first conducted before the State Engineer. Your statement will allow us to waive that hearing requirement.

Please return the application with a letter disclaiming injury between existing well 25557-F and the proposed well.

Also be advised that the driller you have indicated, Murfin Drilling out of Wichita Kansas, is not a licenced water well contractor in Colorado. The water well will have to be completed by a Colorado licenced contractor.

Thank You

RECEIVED

DEC 19 1988

COLO. OIL & GAS CONS. COMM.