

FORM NO.
GWS-31
4/2012

WELL CONSTRUCTION AND TEST REPORT
STATE OF COLORADO, OFFICE OF THE STATE ENGINEER
1313 Sherman St., Ste 821, Denver, CO 80203
Main (303) 866-3581 Fax (303) 866-3589 www.water.state.co.us

For Office Use Only
RECEIVED

SEP 03 2015

WATER RESOURCES
STATE ENGINEER
COLO

1. WELL PERMIT NUMBER: 295200

2. WELL OWNER INFORMATION
NAME OF WELL OWNER: UET MIDSTREAM
MAILING ADDRESS: 225 UNION BLVD Suite 200
CITY: LAKEWOOD STATE: CO ZIP CODE: 80228
TELEPHONE NUMBER w/area code:

3. WELL LOCATION AS DRILLED: SE 1/4, NE 1/4, Sec., 2 Twp. 9 N or S, Range 59 E or W
DISTANCES FROM SEC. LINES: ft. from N or S section line and ft. from E or W section line.
SUBDIVISION: LOT BLOCK FILING (UNIT)
Optional GPS Location: GPS Unit must use the following settings: Format must be UTM, Units must be meters, Datum must be NAD83, Unit must be set to true N, Zone 12 or Zone 13
STREET ADDRESS AT WELL LOCATION:
Owner's Well Designation: Easting: 103 56 15.94 Northing: 40 46 50.34

4. GROUND SURFACE ELEVATION 4968 feet
DATE COMPLETED 7-17-2015 TOTAL DEPTH 130 feet
5. GEOLOGIC LOG:
Depth Type Grain Size Color Water Loc.
0-3' Top Soil
3'-90' CLAY
90'-130' SAND/SANDSTONE 1/4" MINUS TAN
6. HOLE DIAM (in.) From (ft) To (ft)
8" 0 130
7. PLAIN CASING:
OD (in) Kind Wall Size (in) From (ft) To (ft)
5 5/8 PVC .327 5' 90'
6 7/8 STEEL .250 + 1' 19'
PERFORATED CASING: Screen Slot Size (in):
5-5/8 PVC 0.32 90' 130'
8. FILTER PACK: 9. PACKER PLACEMENT:
Material Washed Rock Type
Size 3/8 minus
Interval 80-130 Depth
10. GROUTING RECORD
Material Amount Density Interval Placement
Portland 5XS 9-105 gal 5'-20' TREMIE

Remarks:

11. DISINFECTION: Type 6% Bleach Amt. Used 1 gallon DURING RAILING TIME
12. WELL TEST DATA: Check box if Test Data is submitted on Form Number GWS 39 Supplemental Well Test.
TESTING METHOD Bailers
Static Level 86 ft. Date/Time measured: 7/23/15 8:40 AM, Production Rate 12 gpm.
Pumping Level 106 ft. Date/Time measured: 7/23/15 1:40 PM, Test Length (hrs) 5 hrs.
Remarks: -106-
13. I have read the statements made herein and know the contents thereof, and they are true to my knowledge. This document is signed (or name entered if filing online) and certified in accordance with Rule 17.4 of the Water Well Construction Rules, 2 CCR 402-2. The filing of a document that contains false statements is a violation of section 37-91-108(1)(e), C.R.S., and is punishable by fines up to \$5000 and/or revocation of the contracting license. If filing online the State Engineer considers entering of licensed contractor name to be compliance with Rule 17.4
Company Name: Western Cleanup Corporation Phone w/area code: 970-867-9507 License Number: 1262
Mailing Address: PO Box 1247 Ft Morgan Colorado 80701
Sign (or enter name if filing online) Print Name and Title Date
Karl GARNER VP 8-10-15