



## NFIRS-1 Basic

**A**

06760	CO	01	15	2024	Upper Pine River FPD Station 1 (61)	24UP-0029	0
FDID	State	Month	Day	Year	Station	Number	Exposure

**B Location Type**

Census tract:

Street Address  
 Intersection  
 In Front Of  
 Rear Of  
 Adjacent To  
 Directions  
 US National Grid

405		FANTANGO	LN-Lane	
Number	Prefix	Street or Highway	Street Type	Suffix

	DGO/FloridaMesa	CO	81301
Apt./Suite/Room	City	State	Zip Code

Cross Street

<p><b>C Incident Type</b></p> <p><input style="width: 100%;" type="text" value="220-Overpressure rupture from air or gas, other"/></p> <hr/> <p><b>D Aid Given Or Received</b></p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%; text-align: center;"><input style="width: 100%;" type="text"/></td> <td style="width: 50%; text-align: center;"><input style="width: 100%;" type="text"/></td> </tr> <tr> <td style="text-align: center;">Their FDID</td> <td style="text-align: center;">Their State</td> </tr> <tr> <td colspan="2" style="text-align: center;"><input style="width: 100%;" type="text"/></td> </tr> <tr> <td colspan="2" style="text-align: center;">Their Incident Number</td> </tr> </table> <p> <input type="checkbox"/> 1 Mutual Aid Received  <input type="checkbox"/> 2 Auto. Aid Received  <input type="checkbox"/> 3 Mutual Aid Given  <input type="checkbox"/> 4 Auto. Aid Given  <input type="checkbox"/> 5 Other Aid Given  <input checked="" type="checkbox"/> None       </p>	<input style="width: 100%;" type="text"/>	<input style="width: 100%;" type="text"/>	Their FDID	Their State	<input style="width: 100%;" type="text"/>		Their Incident Number		<p><b>E1 Dates and Times</b></p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>Alarm</td> <td style="text-align: center;">01</td> <td style="text-align: center;">15</td> <td style="text-align: center;">2024</td> <td style="text-align: center;">19:58</td> </tr> <tr> <td>Arrival</td> <td style="text-align: center;">01</td> <td style="text-align: center;">15</td> <td style="text-align: center;">2024</td> <td style="text-align: center;">20:21</td> </tr> <tr> <td>Controlled</td> <td style="text-align: center;">01</td> <td style="text-align: center;">15</td> <td style="text-align: center;">2024</td> <td style="text-align: center;">21:38</td> </tr> <tr> <td>Last Unit Cleared</td> <td style="text-align: center;">01</td> <td style="text-align: center;">15</td> <td style="text-align: center;">2024</td> <td style="text-align: center;">21:42</td> </tr> </table>	Alarm	01	15	2024	19:58	Arrival	01	15	2024	20:21	Controlled	01	15	2024	21:38	Last Unit Cleared	01	15	2024	21:42	<p><b>E2 Shifts and Alarms</b></p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="text-align: center;">C</td> <td style="text-align: center;">1</td> <td style="text-align: center;">UPFPD Zone 6</td> </tr> <tr> <td style="text-align: center;">Shift or Platoon</td> <td style="text-align: center;">Alarms</td> <td style="text-align: center;">District</td> </tr> </table> <hr/> <p><b>E3 Special Studies</b></p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;"></td> <td style="width: 50%;"></td> </tr> <tr> <td style="text-align: center;">ID#</td> <td style="text-align: center;">Value</td> </tr> </table>	C	1	UPFPD Zone 6	Shift or Platoon	Alarms	District			ID#	Value
<input style="width: 100%;" type="text"/>	<input style="width: 100%;" type="text"/>																																							
Their FDID	Their State																																							
<input style="width: 100%;" type="text"/>																																								
Their Incident Number																																								
Alarm	01	15	2024	19:58																																				
Arrival	01	15	2024	20:21																																				
Controlled	01	15	2024	21:38																																				
Last Unit Cleared	01	15	2024	21:42																																				
C	1	UPFPD Zone 6																																						
Shift or Platoon	Alarms	District																																						
ID#	Value																																							

<b>F Actions Taken</b>  <div style="border: 1px solid black; padding: 2px; margin-bottom: 5px;">81-Incident command</div> Primary Action Taken  <div style="border: 1px solid black; padding: 2px; margin-bottom: 5px;">41-Identify, analyze hazardous materials</div> Additional Action Taken  <div style="border: 1px solid black; padding: 2px; margin-bottom: 5px;">42-HazMat detection, monitoring, sampling, &amp; analysis</div> Additional Action Taken	<b>G1 Resources</b> <input checked="" type="checkbox"/> Apparatus or Personnel Module is used.  <table style="width:100%; border-collapse: collapse;"> <tr> <td></td> <td style="text-align: center;">Apparatus</td> <td style="text-align: center;">Personnel</td> </tr> <tr> <td>Suppression</td> <td style="border: 1px solid black; text-align: center;">2</td> <td style="border: 1px solid black; text-align: center;">4</td> </tr> <tr> <td>EMS</td> <td style="border: 1px solid black; text-align: center;">1</td> <td style="border: 1px solid black; text-align: center;">1</td> </tr> <tr> <td>Other</td> <td style="border: 1px solid black; text-align: center;">2</td> <td style="border: 1px solid black; text-align: center;">2</td> </tr> </table> <input type="checkbox"/> Resource counts include aid received resources.		Apparatus	Personnel	Suppression	2	4	EMS	1	1	Other	2	2	<b>G2 Estimated Dollar Losses and Values</b> <b>Losses:</b> Required for all fires if known. Optional for all non-fires. <span style="float: right;">None</span>  Property: \$ <input style="width: 100px;" type="text"/> <input checked="" type="checkbox"/> Contents: \$ <input style="width: 100px;" type="text"/> <input checked="" type="checkbox"/>  <b>Pre-Incident Values:</b> Optional <span style="float: right;">None</span> Property: \$ <input style="width: 100px;" type="text"/> <input checked="" type="checkbox"/> Contents: \$ <input style="width: 100px;" type="text"/> <input checked="" type="checkbox"/>
	Apparatus	Personnel												
Suppression	2	4												
EMS	1	1												
Other	2	2												

<b>Completed Modules</b> <input type="checkbox"/> 2 - Fire <input type="checkbox"/> 3 - Structure Fire <input type="checkbox"/> 4 - Civilian Fire Cas. <input type="checkbox"/> 5 - Fire Service Cas. <input type="checkbox"/> 6 - EMS <input type="checkbox"/> 7 - HazMat <input type="checkbox"/> 8 - Wildland Fire <input type="checkbox"/> 9 - Apparatus <input type="checkbox"/> 10 - Personnel <input type="checkbox"/> 11 - Arson	<b>H1 Casualties</b> <input checked="" type="checkbox"/> None  <table style="width:100%; border-collapse: collapse;"> <tr> <td></td> <td style="text-align: center;">Deaths</td> <td style="text-align: center;">Injuries</td> </tr> <tr> <td>Fire Service</td> <td style="border: 1px solid black; text-align: center;">0</td> <td style="border: 1px solid black; text-align: center;">0</td> </tr> <tr> <td>Civilian</td> <td style="border: 1px solid black; text-align: center;">0</td> <td style="border: 1px solid black; text-align: center;">0</td> </tr> </table> <b>H2 Detector</b> Required for Confined Fires <input type="checkbox"/> 1 - Detector Alerted Occupants <input type="checkbox"/> 2 - Detector Did Not Alert Them <input type="checkbox"/> 3 - Unknown		Deaths	Injuries	Fire Service	0	0	Civilian	0	0	<b>H3 Hazardous Materials Release</b> <input checked="" type="checkbox"/> 1 - Natural Gas <input type="checkbox"/> 2 - Propane Gas <input type="checkbox"/> 3 - Gasoline <input type="checkbox"/> 4 - Kerosene <input type="checkbox"/> 5 - Diesel Fuel / Fuel Oil <input type="checkbox"/> 6 - Household Solvents <input type="checkbox"/> 7 - Motor Oil <input type="checkbox"/> 8 - Paint <input type="checkbox"/> 0 - Other <input type="checkbox"/> None	<b>I Mixed Use Property</b> <input type="checkbox"/> Not Mixed <input type="checkbox"/> 10 - Assembly Use <input type="checkbox"/> 20 - Education Use <input type="checkbox"/> 33 - Medical Use <input type="checkbox"/> 40 - Residential Use <input type="checkbox"/> 51 - Row Of Stores <input type="checkbox"/> 53 - Enclosed Mall <input type="checkbox"/> 58 - Business and Residential <input type="checkbox"/> 59 - Office Use <input type="checkbox"/> 60 - Industrial Use <input type="checkbox"/> 63 - Military Use <input type="checkbox"/> 65 - Farm Use <input type="checkbox"/> 00 - Other Mixed Use
	Deaths	Injuries										
Fire Service	0	0										
Civilian	0	0										

<b>J Property Use</b> <input type="checkbox"/> None <b>Structures</b> 131 <input type="checkbox"/> Church, Place of Worship 161 <input type="checkbox"/> Restaurant or Cafeteria 162 <input type="checkbox"/> Bar/Tavern or Nightclub 213 <input type="checkbox"/> Elementary School, Kindergarten 215 <input type="checkbox"/> High School, Junior High 241 <input type="checkbox"/> College, Adult Education 311 <input type="checkbox"/> Nursing Home 331 <input type="checkbox"/> Hospital	341 <input type="checkbox"/> Clinic, Clinic-Type Infirmary 342 <input type="checkbox"/> Doctor/Dentist Office 361 <input type="checkbox"/> Prison or Jail, Not Juvenile 419 <input type="checkbox"/> 1- or 2-Family Dwelling 429 <input type="checkbox"/> MultiFamily Dwelling 439 <input type="checkbox"/> Rooming/Boarding House 449 <input type="checkbox"/> Commerical Hotel or Motel 459 <input type="checkbox"/> Residential, Board and Care 464 <input type="checkbox"/> Dormitory/Barracks 519 <input type="checkbox"/> Food and Beverage Sales	539 <input type="checkbox"/> Household Goods, Sales, Repairs 571 <input type="checkbox"/> Gas or Service Station 579 <input type="checkbox"/> Motor Vehicle/Boat Sales/Repairs 599 <input type="checkbox"/> Business Office 615 <input type="checkbox"/> Electric-Generating Plant 629 <input type="checkbox"/> Laboratory/Science Laboratory 700 <input type="checkbox"/> Manufacturing Plant 819 <input type="checkbox"/> Livestock/Poultry Storage (Barn) 882 <input type="checkbox"/> Non-Residential Parking Garage 891 <input type="checkbox"/> Warehouse
---	--	--

<b>Outside</b> 124 <input type="checkbox"/> Playground or Park 655 <input type="checkbox"/> Crops or Orchard 669 <input type="checkbox"/> Forest (Timberland) 807 <input type="checkbox"/> Outdoor Storage Area 919 <input type="checkbox"/> Dump or Sanitary Landfill 931 <input type="checkbox"/> Open Land or Field 936 <input type="checkbox"/> Vacant Lot	938 <input type="checkbox"/> Graded/Cared for Plot of Land 946 <input type="checkbox"/> Lake, River, Stream 951 <input type="checkbox"/> Railroad Right-of-Way 960 <input type="checkbox"/> Other Street 961 <input type="checkbox"/> Highway/Divided Highway 962 <input type="checkbox"/> Residential Street/Driveway 981 <input type="checkbox"/> Construction Site 984 <input type="checkbox"/> Industrial Plant Yard	<b>Property Use:</b> <div style="border: 1px solid black; padding: 2px; margin-bottom: 5px;">982-Oil or gas field</div> <b>Description</b> Look up and enter a Property Use code and description only if you have NOT checked a Property Use box.
---	---	---

K2

**Owner**

Corporate Principal Owner	Simcoe LLC	9038182260		
Local Option	Person/Entity Type	Business Name (if applicable)	Phone Number	
	Shoemaker Well	01-34-1		
Mr., Ms., Mrs.	First Name	MI	Last Name	Suffix
1199		Main	ST-Street	
Number	Prefix	Street or Highway	Street Type	Suffix
	101		City of Durango	
Post Office Box	Apt./Suite/Room		City	
CO	81301			
State	Zip Code			

**L Remarks:**

E61, M61, E65, and EMS60 dispatched to a gas well leak. 601 and 602 added to record. Weather clear, roads dry, location in District 6, distance delayed enroute times. Spot weather check for long/lat was given by dispatch with light winds from the north, gusting to 12, RH of 22, temp 15F. Enroute 601 instructed E65 to proceed to RP address, E61 and M61 would proceed to well location. Approaching from west upwind 601 first on scene, established command. E61 proceeded to a possible secondary well pad. Access was limited to snow being pushed over the gate. 601 proceeded to location 1 to check access. 601 advised that access could be made. E61 proceeded to location. M61 advised to stay at staging. E61 arrived and bunked out in full PPE and proceeded to well pad with gas monitor. E61 found Shoemaker Well Number 01-34-1 operated by Simcoe LLC with a 1/2" line sticking out of bottom of locked shed that was venting gas crystalizing in the cold to open atmosphere. Pipeline was tagged and lock-out/tag-out measures where in place. Flammable atmosphere detected with four gas meter by Upper Pine crew 25 feet onto the well pad. Retreated to safe area and advised two homes to shelter in place. No gas at those homes outside when sampled. Advised by 601 and established perimeter around well pad. All houses were advised to shelter in place. Simcoe emergency number contacted by 601 and dispatch immediately sent a tech from Aztec. Tech arrived and well remotely shut down and flammable a...

Full primary narrative can be found in NFIRS 1S - Supplemental

**M Authorization**

139	Kelly, Jeremy	Captain/EMT		01/22/2024
Officer In Charge ID	Signature	Position or Rank	Assignment	Date
139	Kelly, Jeremy	Captain/EMT		01/22/2024
Member Making Report ID	Signature	Position or Rank	Assignment	Date

# NFIRS-7 HazMat

**A**

06760	CO	01	15	2024	Upper Pine River FPD Station 1 (61)	24UP-0029	0
FDID	State	Month	Day	Year	Station	Number	Exposure

**B**

**HazMat ID**

UN #	21-Division 2.1 Flammable gases	CAS Registration #	Natural gas
UN #	DOT Hazard Classification	CAS Registration #	Chemical Name

<p><b>C1</b></p> <p><b>Container Type</b></p> <div style="border: 1px solid black; padding: 2px; margin-bottom: 5px;">22-Pipe or pipeline</div> <p><input type="checkbox"/> None</p>	<p><b>C2</b></p> <p><b>Estimated Container Capacity</b></p> <div style="border: 1px solid black; width: 20px; height: 20px; margin-bottom: 5px;"></div> <p><b>C3</b></p> <p><b>Units: Capacity</b></p> <table style="width: 100%;"> <tr> <td style="text-align: center;">Volume</td> <td style="text-align: center;">Weight</td> </tr> <tr> <td><input type="checkbox"/> 11 - Ounces</td> <td><input type="checkbox"/> 21 - Ounces</td> </tr> <tr> <td><input type="checkbox"/> 12 - Gallons</td> <td><input type="checkbox"/> 22 - Pounds</td> </tr> <tr> <td><input type="checkbox"/> 13 - Barrels</td> <td><input type="checkbox"/> 23 - Grams</td> </tr> <tr> <td><input type="checkbox"/> 14 - Liters</td> <td><input type="checkbox"/> 24 - Kilograms</td> </tr> <tr> <td><input checked="" type="checkbox"/> 15 - Cubic Feet</td> <td></td> </tr> <tr> <td><input type="checkbox"/> 16 - Cubic Meters</td> <td></td> </tr> </table>	Volume	Weight	<input type="checkbox"/> 11 - Ounces	<input type="checkbox"/> 21 - Ounces	<input type="checkbox"/> 12 - Gallons	<input type="checkbox"/> 22 - Pounds	<input type="checkbox"/> 13 - Barrels	<input type="checkbox"/> 23 - Grams	<input type="checkbox"/> 14 - Liters	<input type="checkbox"/> 24 - Kilograms	<input checked="" type="checkbox"/> 15 - Cubic Feet		<input type="checkbox"/> 16 - Cubic Meters		<p><b>D1</b></p> <p><b>Estimated Amount Released</b></p> <div style="border: 1px solid black; width: 20px; height: 20px; margin-bottom: 5px;"></div> <p><b>D2</b></p> <p><b>Units: Released</b></p> <table style="width: 100%;"> <tr> <td style="text-align: center;">Volume</td> <td style="text-align: center;">Weight</td> </tr> <tr> <td><input type="checkbox"/> 11 - Ounces</td> <td><input type="checkbox"/> 21 - Ounces</td> </tr> <tr> <td><input type="checkbox"/> 12 - Gallons</td> <td><input type="checkbox"/> 22 - Pounds</td> </tr> <tr> <td><input type="checkbox"/> 13 - Barrels</td> <td><input type="checkbox"/> 23 - Grams</td> </tr> <tr> <td><input type="checkbox"/> 14 - Liters</td> <td><input type="checkbox"/> 24 - Kilograms</td> </tr> <tr> <td><input checked="" type="checkbox"/> 15 - Cubic Feet</td> <td></td> </tr> <tr> <td><input type="checkbox"/> 16 - Cubic Meters</td> <td></td> </tr> </table>	Volume	Weight	<input type="checkbox"/> 11 - Ounces	<input type="checkbox"/> 21 - Ounces	<input type="checkbox"/> 12 - Gallons	<input type="checkbox"/> 22 - Pounds	<input type="checkbox"/> 13 - Barrels	<input type="checkbox"/> 23 - Grams	<input type="checkbox"/> 14 - Liters	<input type="checkbox"/> 24 - Kilograms	<input checked="" type="checkbox"/> 15 - Cubic Feet		<input type="checkbox"/> 16 - Cubic Meters		<p><b>E1</b></p> <p><b>Physical State When Released</b></p> <p><input type="checkbox"/> 1 - Solid</p> <p><input type="checkbox"/> 2 - Liquid</p> <p><input checked="" type="checkbox"/> 3 - Gas</p> <p><input type="checkbox"/> U - Undetermined</p> <hr/> <p><b>E2</b></p> <p><b>Released Into</b></p> <div style="border: 1px solid black; padding: 2px; width: 50px;">1-Air</div>
Volume	Weight																														
<input type="checkbox"/> 11 - Ounces	<input type="checkbox"/> 21 - Ounces																														
<input type="checkbox"/> 12 - Gallons	<input type="checkbox"/> 22 - Pounds																														
<input type="checkbox"/> 13 - Barrels	<input type="checkbox"/> 23 - Grams																														
<input type="checkbox"/> 14 - Liters	<input type="checkbox"/> 24 - Kilograms																														
<input checked="" type="checkbox"/> 15 - Cubic Feet																															
<input type="checkbox"/> 16 - Cubic Meters																															
Volume	Weight																														
<input type="checkbox"/> 11 - Ounces	<input type="checkbox"/> 21 - Ounces																														
<input type="checkbox"/> 12 - Gallons	<input type="checkbox"/> 22 - Pounds																														
<input type="checkbox"/> 13 - Barrels	<input type="checkbox"/> 23 - Grams																														
<input type="checkbox"/> 14 - Liters	<input type="checkbox"/> 24 - Kilograms																														
<input checked="" type="checkbox"/> 15 - Cubic Feet																															
<input type="checkbox"/> 16 - Cubic Meters																															

<p><b>F1</b></p> <p><b>Released From</b></p> <p><input type="checkbox"/> Below Grade</p> <p><input type="checkbox"/> 1 - Inside/On Structure</p> <p><input checked="" type="checkbox"/> 2 - Outside of Structure</p>	<p><b>F2</b></p> <p><b>Population Density</b></p> <p><input type="checkbox"/> 1 - Urban</p> <p><input type="checkbox"/> 2 - Suburban</p> <p><input checked="" type="checkbox"/> 3 - Rural</p>	<p><b>G2</b></p> <p><b>Area Evacuated</b></p> <p><input checked="" type="checkbox"/> 1 - Square Feet</p> <p><input type="checkbox"/> 2 - Blocks</p> <p><input type="checkbox"/> 3 - Square Miles</p> <div style="border: 1px solid black; width: 50px; text-align: center; margin-top: 5px;">2500</div>	<p><b>H</b></p> <p><b>HazMat Actions Taken</b></p> <div style="border: 1px solid black; padding: 2px; margin-bottom: 5px;">11-Identify, analyze hazardous materials</div> <div style="border: 1px solid black; padding: 2px; margin-bottom: 5px;">12-HazMat detection, monitoring, sampling, &amp; analysis</div> <div style="border: 1px solid black; padding: 2px;">22-Isolate area &amp; establish hazard control zones</div>
	<p><b>G1</b></p> <p><b>Area Affected</b></p> <p><input checked="" type="checkbox"/> 1 - Square Feet</p> <p><input type="checkbox"/> 2 - Blocks</p> <p><input type="checkbox"/> 3 - Square Miles</p> <div style="border: 1px solid black; width: 50px; text-align: center; margin-top: 5px;">500</div>	<p><b>G3</b></p> <p><b>Estimated Number of People Evacuated</b></p> <div style="border: 1px solid black; width: 50px; text-align: center; margin-top: 5px;">0</div>	<p><b>I</b></p> <p><b>If Fire or Explosion Is Involved With a Release, Which Occurred First?</b></p> <p><input type="checkbox"/> 1 - Ignition</p> <p><input checked="" type="checkbox"/> 2 - Release</p> <p><input type="checkbox"/> 3 - Undetermined</p>
		<p><b>G4</b></p> <p><b>Estimated Number of Buildings Evacuated</b></p> <div style="border: 1px solid black; width: 50px; text-align: center; margin-top: 5px;">0</div>	

<p><b>J</b></p> <p><b>Cause of Release</b></p> <p><input type="checkbox"/> 1 - Intentional</p> <p><input checked="" type="checkbox"/> 2 - Unintentional Release</p> <p><input type="checkbox"/> 3 - Container/Containment Failure</p> <p><input type="checkbox"/> 4 - Act of Nature</p> <p><input type="checkbox"/> 5 - Cause Under Investigation</p> <p><input type="checkbox"/> U - Cause Undetermined After Investigation</p>	<p><b>K</b></p> <p><b>Factors Contributing To Release</b></p> <div style="border: 1px solid black; padding: 2px; margin-top: 5px;">78-Equipment not being operated properly</div>	<p><b>L</b></p> <p><b>Factors Affecting Mitigation</b></p> <div style="border: 1px solid black; padding: 2px; margin-bottom: 5px;">46-Extreme low temperature</div> <div style="border: 1px solid black; padding: 2px;">47-Ice or snow conditions</div>
--	---	---

<p><b>M</b></p> <p><b>Equipment Involved In Release</b></p> <p><input type="text" value="342-Gas compressor"/></p> <p>Equipment Involved In Release  <input type="checkbox"/> None</p> <p>Brand <input type="text"/></p> <p>Model <input type="text"/></p> <p>Serial <input type="text"/></p> <p>Year <input type="text"/></p>	<p><b>N</b></p> <p><b>Mobile Property Involved In Release</b></p> <p><input type="text"/></p> <p>Type <input type="text"/></p> <p><input type="text"/></p> <p>Make</p> <p>Model <input type="text"/></p> <p>Year <input type="text"/></p> <p>License # <input type="text"/></p> <p>State <input type="text"/></p> <p>DOT/ICC # <input type="text"/></p>	<p><b>O</b></p> <p><b>HazMat Disposition</b></p> <p><input type="checkbox"/> 1 - Completed by Fire Service Only</p> <p><input checked="" type="checkbox"/> 2 - Completed w/Fire Service Present</p> <p><input type="checkbox"/> 3 - Released to Local Agency</p> <p><input type="checkbox"/> 4 - Released to County Agency</p> <p><input type="checkbox"/> 5 - Released to State Agency</p> <p><input type="checkbox"/> 6 - Released to Federal Agency</p> <p><input type="checkbox"/> 7 - Released to Private Agency</p> <p><input type="checkbox"/> 8 - Released to Property Owner or Manager</p> <hr/> <p><b>P</b></p> <p><b>HazMat Civilian Casualties</b></p> <p>Deaths <input type="text" value="0"/> Injuries <input type="text" value="0"/></p>
--	---	---

## NFIRS-9 Apparatus or Resources

A

06760	CO	01	15	2024	Upper Pine River FPD Station 1 (61)	24UP-0029	0
FDID	State	Month	Day	Year	Station	Number	Exposure

B Apparatus/Resource	Dates/Times	Sent	Number of People	Apparatus Use	Actions Taken
ID: <input type="text" value="601"/> Type: <input type="text" value="92-Chief officer car"/>	Dispatch: <input type="text" value="01/15/2024"/> <input type="text" value="19:58"/> Arrival: <input type="text" value="01/15/2024"/> <input type="text" value="20:21"/> Clear: <input type="text" value="01/15/2024"/> <input type="text" value="21:42"/>	<input checked="" type="checkbox"/> Sent	<input type="text" value="1"/>	<input type="checkbox"/> Suppression <input type="checkbox"/> EMS <input checked="" type="checkbox"/> Other	<input type="text" value="81-Incident command"/>
ID: <input type="text" value="602"/> Type: <input type="text" value="92-Chief officer car"/>	Dispatch: <input type="text" value="01/15/2024"/> <input type="text" value="19:58"/> Arrival: <input type="text" value="01/15/2024"/> <input type="text" value="20:21"/> Clear: <input type="text" value="01/15/2024"/> <input type="text" value="21:42"/>	<input checked="" type="checkbox"/> Sent	<input type="text" value="1"/>	<input type="checkbox"/> Suppression <input type="checkbox"/> EMS <input checked="" type="checkbox"/> Other	<input type="text" value="73-Provide manpower"/>
ID: <input type="text" value="E61"/> Type: <input type="text" value="11-Engine"/>	Dispatch: <input type="text" value="01/15/2024"/> <input type="text" value="19:58"/> Arrival: <input type="text" value="01/15/2024"/> <input type="text" value="20:21"/> Clear: <input type="text" value="01/15/2024"/> <input type="text" value="21:42"/>	<input checked="" type="checkbox"/> Sent	<input type="text" value="2"/>	<input checked="" type="checkbox"/> Suppression <input type="checkbox"/> EMS <input type="checkbox"/> Other	<input type="text" value="44-Hazardous materials leak control &amp; containment"/> <input type="text" value="42-HazMat detection, monitoring, sampling, &amp; analysis"/> <input type="text" value="41-Identify, analyze hazardous materials"/>
ID: <input type="text" value="E65"/> Type: <input type="text" value="11-Engine"/>	Dispatch: <input type="text" value="01/15/2024"/> <input type="text" value="19:58"/> Arrival: <input type="text" value="01/15/2024"/> <input type="text" value="20:21"/> Clear: <input type="text" value="01/15/2024"/> <input type="text" value="20:36"/>	<input checked="" type="checkbox"/> Sent	<input type="text" value="2"/>	<input checked="" type="checkbox"/> Suppression <input type="checkbox"/> EMS <input type="checkbox"/> Other	<input type="text" value="53-Evacuate area"/> <input type="text" value="55-Establish safe area"/> <input type="text" value="74-Provide apparatus"/> <input type="text" value="73-Provide manpower"/>
ID: <input type="text" value="M61"/> Type: <input type="text" value="76-ALS unit"/>	Dispatch: <input type="text" value="01/15/2024"/> <input type="text" value="19:58"/> Arrival: <input type="text" value="01/15/2024"/> <input type="text" value="20:21"/> Clear: <input type="text" value="01/15/2024"/> <input type="text" value="21:42"/>	<input checked="" type="checkbox"/> Sent	<input type="text" value="1"/>	<input type="checkbox"/> Suppression <input checked="" type="checkbox"/> EMS <input type="checkbox"/> Other	<input type="text" value="92-Standby"/>

# NFIRS-10 Personnel

A	06760	CO	01	15	2024	Upper Pine River FPD Station 1 (61)	24UP-0029	0
	FDID	State	Month	Day	Year	Station	Number	Exposure

<b>B</b>		<b>Apparatus/Resource</b>		<b>Dates/Times</b>		<b>Sent</b>		<b>Number of People</b>		<b>Apparatus Use</b>		<b>Actions Taken</b>	
ID:	601	Dispatch:	01/15/2024	19:58	<input checked="" type="checkbox"/> Sent		1	<input type="checkbox"/> Suppression	<input type="checkbox"/> EMS	<input checked="" type="checkbox"/> Other	81-Incident command		
Type:	92-Chief officer car	Arrival:	01/15/2024	20:21									
		Clear:	01/15/2024	21:42									
Personnel ID	Name		Rank		Role		Attend		Actions Taken				
011	Evans, Bruce		Fire Chief/Paramedic		5588002-Officer		<input type="checkbox"/>		81-Incident command				

ID:	602	Dispatch:	01/15/2024	19:58	<input checked="" type="checkbox"/> Sent		1	<input type="checkbox"/> Suppression	<input type="checkbox"/> EMS	<input checked="" type="checkbox"/> Other	73-Provide manpower		
Type:	92-Chief officer car	Arrival:	01/15/2024	20:21									
		Clear:	01/15/2024	21:42									
Personnel ID	Name		Rank		Role		Attend		Actions Taken				
160	French, Greg		Deputy Chief		5588002-Officer		<input type="checkbox"/>		73-Provide manpower				

ID:	E61	Dispatch:	01/15/2024	19:58	<input checked="" type="checkbox"/> Sent		2	<input checked="" type="checkbox"/> Suppression	<input type="checkbox"/> EMS	<input type="checkbox"/> Other	44-Hazardous materials leak control & containment		
Type:	11-Engine	Arrival:	01/15/2024	20:21							42-HazMat detection, monitoring, sampling, & analysis		
		Clear:	01/15/2024	21:42							41-Identify, analyze hazardous materials		
Personnel ID	Name		Rank		Role		Attend		Actions Taken				
139	Kelly, Jeremy		Captain/EMT		5588002-Officer		<input type="checkbox"/>		44-Hazardous materials leak control & containment				
											42-HazMat detection, monitoring, sampling, & analysis		
											41-Identify, analyze hazardous materials		
119	Panawa, Chris		Engineer		5588001-Driver		<input type="checkbox"/>		44-Hazardous materials leak control & containment				
											42-HazMat detection, monitoring, sampling, & analysis		
											41-Identify, analyze hazardous materials		

ID:	E65	Dispatch:	01/15/2024	19:58	<input checked="" type="checkbox"/> Sent		2	<input checked="" type="checkbox"/> Suppression	<input type="checkbox"/> EMS	<input type="checkbox"/> Other	53-Evacuate area		
Type:	11-Engine	Arrival:	01/15/2024	20:21							55-Establish safe area		
		Clear:	01/15/2024	20:36							74-Provide apparatus		
											73-Provide manpower		
Personnel ID	Name		Rank		Role		Attend		Actions Taken				
073	Muir, Mike		Captain		5588002-Officer		<input type="checkbox"/>		53-Evacuate area				
											55-Establish safe area		
											74-Provide apparatus		
											73-Provide manpower		

166	Rhodes, Jake	FF/EMT-B	5588001-Driver	<input type="checkbox"/>	53-Evacuate area
					55-Establish safe area
					74-Provide apparatus
					73-Provide manpower

ID:	M61	Dispatch:	01/15/2024	19:58	<input checked="" type="checkbox"/> Sent	1	<input type="checkbox"/> Suppression	92-Standby
Type:	76-ALS unit	Arrival:	01/15/2024	20:21			<input checked="" type="checkbox"/> EMS	
		Clear:	01/15/2024	21:42			<input type="checkbox"/> Other	

Personnel ID	Name	Rank	Role	Attend	Actions Taken
147	Cogburn, Aaron	FF/PM	5588001-Driver	<input type="checkbox"/>	92-Standby

# NFIRS-1S Supplemental

A

06760	CO	01	15	2024	Upper Pine River FPD Station 1 (61)	24UP-0029	0
FDID	State	Month	Day	Year	Station	Number	Exposure

## Primary Narrative:

E61, M61, E65, and EMS60 dispatched to a gas well leak. 601 and 602 added to record. Weather clear, roads dry, location in District 6, distance delayed enroute times. Spot weather check for long/lat was given by dispatch with light winds from the north, gusting to 12, RH of 22, temp 15F. Enroute 601 instructed E65 to proceed to RP address, E61 and M61 would proceed to well location. Approaching from west upwind 601 first on scene, established command. E61 proceeded to a possible secondary well pad. Access was limited to snow being pushed over the gate. 601 proceeded to location 1 to check access. 601 advised that access could be made. E61 proceeded to location. M61 advised to stay at staging. E61 arrived and bunked out in full PPE and proceeded to well pad with gas monitor. E61 found Shoemaker Well Number 01-34-1 operated by Simcoe LLC with a 1/2" line sticking out of bottom of locked shed that was venting gas crystalizing in the cold to open atmosphere. Pipeline was tagged and lock-out/tag-out measures where in place. Flammable atmosphere detected with four gas meter by Upper Pine crew 25 feet onto the well pad. Retreated to safe area and advised two homes to shelter in place. No gas at those homes outside when sampled. Advised by 601 and established perimeter around well pad. All houses were advised to shelter in place. Simcoe emergency number contacted by 601 and dispatch immediately sent a tech from Aztec. Tech arrived and well remotely shut down and flammable atmosphere dissipated. Tech made entry and closed value. Hazard controlled under fire district supervision. Resampling did not indicate any flammable gas. Well pad tech was able to open shed and isolate valve. E61 advised 601. Relay to RP via E65, and southern residents advised of leak stopped. 601 cleared all units, returned to service.