

State of Colorado
Energy & Carbon Management Commission

1120 Lincoln Street, Suite 801, Denver, Colorado 80203
Phone: (303) 894-2100 Fax: (303) 894-2109



Document Number:

403787197

Date Received:

06/12/2024

FIR RESOLUTION FORM

Overall Status: CAC

CA Summary:

3 of 3 CAs from the FIR responded to on this Form

3 CA Completed
0 Factual Review Request

OPERATOR INFORMATION

ECMC Operator Number: 96850

Name of Operator: TEP ROCKY MOUNTAIN LLC

Address: 1058 COUNTY ROAD 215

City: PARACHUTE State: CO Zip: 81635

Contact Name and Telephone:

Name: _____

Phone: () _____ Fax: () _____

Email: _____

Additional Operator Contact:

Contact Name

Phone

Email

TEP

COGCCInspectionReports@terraep.com

ECMC INSPECTION SUMMARY:

FIR Document Number: 708903205

Inspection Date: 03/05/2024

FIR Submit Date: 03/05/2024

FIR Status: _____

Inspected Operator Information:

Company Name: TEP ROCKY MOUNTAIN LLC

Company Number: 96850

Address: 1058 COUNTY ROAD 215

City: PARACHUTE State: CO Zip: 81635

LOCATION - Location ID: 322510

Location Name: MOBILE-66S92W Number: 20NESW County: _____

Qtrqtr: NESW Sec: 20 Twp: 6S Range: 92W Meridian: 6

Latitude: 39.509370 Longitude: -107.693624

FACILITY - API Number: 05-045- -00 Facility ID: 322510

Facility Name: MOBILE-66S92W Number: 20NESW

Qtrqtr: NESW Sec: 20 Twp: 6S Range: 92W Meridian: 6

Latitude: 39.509370 Longitude: -107.693624

CORRECTIVE ACTIONS:

1 ☒ CA# 192669

Corrective Action: Comply with CECMC wildlife rules

Date: 03/12/2024

Response: CA COMPLETED

Date of Completion: 05/02/2024

Operator Comment: Barbed wire fence has been picked up and repaired. Corrective Action complete.

ECMC Decision: Approved pending re-inspection

	ECMC Representative:		
2	<input checked="" type="checkbox"/> CA# 192670		
Corrective Action:		Comply with CECMC pressure safety device rules	Date: 01/22/2024
Response:		CA COMPLETED	Date of Completion: 05/02/2024
Operator Comment:		PRV and rupture disc vents have been capped. Corrective Action complete.	
ECMC Decision:		Approved pending re-inspection	
ECMC Representative:			

3	<input checked="" type="checkbox"/> CA# 192671		
Corrective Action:		Comply with CECMC labeling rules	Date: 04/04/2024
Response:		CA COMPLETED	Date of Completion: 05/02/2024
Operator Comment:		Tank label has been repaired/replaced. Corrective Action complete.	
ECMC Decision:		Approved pending re-inspection	
ECMC Representative:			

OPERATOR COMMENT AND SUBMITTAL	
Comment:	CA #192669: Barbed wire fence has been picked up and repaired. Corrective Action complete. CA #192670: PRV and rupture disc vents have been capped. Corrective Action complete. CA #192671: Tank label has been repaired/replaced. Corrective Action complete.
I hereby certify that the statements made in this form are, to the best of my knowledge, true, correct, and complete.	
Print Name: Jordan Veith	Signed: _____
Title: TEP Representative	Date: 6/12/2024 7:59:30 AM

ATTACHMENT LIST

View Attachments in Imaged Documents on ECMC website (<http://ecmcweblink.state.co.us/>) - Search by Document Number.

Document Number	Description
403787197	FIR RESOLUTION SUBMITTED

Total Attach: 1 Files