

Operator: XOG

Location Name: Varra 5-I Pad

Loc ID: 430411

Inspection: 697010202





CA: North row of 400 bbl crude oil tanks and both 400 bbl produced water tanks contents and capacity placards have faded and are illegible, see attached photos. Install sign to comply with Rule 605.h.

CA Resolution: Operator has reported that capacity, contents and NFPA labels have been appropriately installed on identified tanks to comply with the 600 series.





CA: Install wildlife screens on separator #10, see attached photo. Install wildlife screen per Rule 608.b.(7).

CA Resolution: Operator has reported that netting has been installed on burner at separator 10 to comply with the 600 series.

CA: Install wildlife screens on the large ECD air inlets to prevent access, see attached photos. Install wildlife screen per Rule 608.b.(7).

CA Resolution: Operator has reported that they have closed doors on the QTI to prevent access to the interior of unit to comply with the 600 series.