

WELL CONSTRUCTION AND TEST REPORT
 STATE OF COLORADO, OFFICE OF THE STATE ENGINEER
 1313 Sherman St., Rm 818, Denver, CO 80203

For Office Use only

RECEIVED

JUN 13 2003

WATER RESOURCES
 STATE ENGINEER
 COLO.

0494289

1. WELL PERMIT NUMBER 243420

2. OWNER NAME(S) Freund Investments LLC
 Mailing Address 15460 E Batavia Dr
 City, St. Zip Aurora, CO 80011
 Phone () (303)341-9310

3. WELL LOCATION AS DRILLED: NE 1/4 SE 1/4, Sec. 8 Twp. 6N Range 64W 6th
 DISTANCES FROM SEC. LINES:
1950 ft. from South Sec. line. and 200 ft. from East Sec. line. OR
(north or south) (east or west)
 Hillside Ranches Amended LOT 12 BLOCK FILING(UNIT)
 STREET ADDRESS AT WELL LOCATION:

4. GROUND SURFACE ELEVATION ft. DRILLING METHOD Mud Rotary
 DATE COMPLETED 5/16/03 TOTAL DEPTH 460 ft. DEPTH COMPLETED 460 ft.

5. GEOLOGIC LOG:

Depth	Description of Material (Type, Size, Color, Water Location)
0-35	Topsoil tan clay white sharp sandstone
35-45	Tan clay
45-70	White sand tan clay
70-85	Tan clay
85-95	White sand tan clay
95-140	Blue green clay shale
140-150	White gray clay
150-205	Blue gray tan clay shale small white sand layers
205-255	Blue gray sand layers blue clay
255-275	Coarse to fine blue gray sand gravel
275-300	Blue shale clay
300-320	Fine blue gray quartz
320-335	Fine blue gray quartz blue gray clay & coal
335-360	Blue gray shale
360-375	Blue gray fine to coarse quartz
375-400	Tan sand clay blue shale mix
400-440	Fine to coarse quartz
440-460	Blue gray green shale coal

REMARKS:

6. HOLE DIAM. (in.) From (ft) To (ft)

Hole Diam. (in.)	From (ft)	To (ft)
10	0	41
6 1/2	41	460

7. PLAIN CASING

OD (in)	Kind	Wall Size	From(ft)	To(ft)
7	Steel	0.188	+1	41
4.5"	PVC	0.227	10	310
4.5"	PVC	0.227	310	460

PERF. CASING: Screen Slot Size: 0.022

8. FILTER PACK:
 Material Pea Gravel
 Size 1/4" minus
 Interval 460-300

9. PACKER PLACEMENT:
 Type
 Depth

10. GROUTING RECORD:

Material	Amount	Density	Interval	Placement
Cement	300 lbs	21 Gal	41-10	tremied
Cement	300 lbs	21 Gal	300-260	tremied
Cement	280 lbs	14 gal	40-10	

11. DISINFECTION: Type HTH Amt. Used 8 oz

12. WELL TEST DATA: Check box if Test Data is submitted on Form No. GWS 39 Supplemental Well Test.
 TESTING METHOD Air
 Static Level 250 ft. Date/Time measured 5/19/03, Production Rate 9 gpm.
 Pumping level 400 ft. Date/Time measured 5/19/03, Test length (hrs.) 4
 Remarks

13. I have read the statements made herein and know the contents thereof, and that they are true to my knowledge. [Pursuant to Section 24-4-104 (13)(a) C.R.S., the making of false statements herein constitutes perjury in the second degree and is punishable as a class 1 misdemeanor.]

CONTRACTOR Can-America Drilling, Inc. Phone (719) 541-2967 Lic. No. 1149
 Mailing Address Box 416 Simla, CO 80835

Name/Title (Please type or print) Wayne Arde V.P. Signature Wayne Arde Date 05/19/03