

**UTAH GAS OP LTD DBA UTAH GAS CORP  
SOUTH CANYON-FEDERAL-67S104W 2NWN  
Facility # 322299**



**UTAH GAS OP LTD DBA UTAH GAS CORP  
SOUTH CANYON-FEDERAL-67S104W 2NWNE  
Facility # 322299**



**Storm water in tank berm.**

**Damaged paint on bottom of tank.**



**Storm water in tank berm.**

**Damaged paint on bottom of tank.**

**UTAH GAS OP LTD DBA UTAH GAS CORP  
SOUTH CANYON-FEDERAL-67S104W 2NWNE  
Facility # 322299**



**Storm water in tank berm.**

**Damaged paint on bottom of tank.**



**Storm water in tank berm.**

**Damaged paint on bottom of tank.**

**UTAH GAS OP LTD DBA UTAH GAS CORP  
SOUTH CANYON-FEDERAL-67S104W 2NWNE  
Facility # 322299**



**Unpainted rusty lines.**



**Riser line has coating material damage.**

**UTAH GAS OP LTD DBA UTAH GAS CORP  
SOUTH CANYON-FEDERAL-67S104W 2NWNE  
Facility # 322299**



**Turbines are off 3 of the 7 vents.**



**Turbine off of vent.**

**UTAH GAS OP LTD DBA UTAH GAS CORP  
SOUTH CANYON-FEDERAL-67S104W 2NWNE  
Facility # 322299**



**Turbine off of vent.**



**Vent line hole is not in the ground securely.**

**UTAH GAS OP LTD DBA UTAH GAS CORP  
SOUTH CANYON-FEDERAL-67S104W 2NWNE  
Facility # 322299**

