


Facility # 430890



**BALLANTINE TRANSFER
STATION**
TOWNSHIP 037N RANGE 107W
LATITUDE 37.15424
LONGITUDE 107.84770
 **Hilcorp Energy Company**
EMERGENCY CONTACT (505) 324-5170 OR 911

NOTICE
GAS DETECTION
(GAS-O₂ LEL, H₂S, CO)
**REQUIRED BEYOND
THIS POINT**
POTENTIAL PROPANE VAPORS
MAY EXIST IN LOW LYING AREAS

5/20/26 12:23
37.1543N 107.8477W



Facility # 430890



Southwest corner of secondary containment is inadequate to contain spill. Hole in containment



COLORADO
Energy & Carbon Management
Commission
Department of Natural Resources

Facility # 430890



Southwest corner of secondary containment is inadequate to contain spill. Hole in containment



Facility # 430890



5/20/26 12:25
37.1543N 107.8477W



Facility # 430890



5/20/26 12:25
37.1543N 107.8476W



Facility # 430890



5/20/26 12:26
37.1542N 107.8478W



COLORADO
Energy & Carbon Management
Commission
Department of Natural Resources

Facility # 430890



5/20/26 12:26
37.1543N 107.8477W

